

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110 001**

No. F6/DFS/MS/2015/S2/170

Dated: 05/02/15

**FIRE SAFETY CERTIFICATE**

Certified that Fair Field, Institute of Management & Technology, FIMT Campus, Kapashera, New Delhi-110037, comprised of basement, ground plus three upper floors(three blocks) and basement, ground plus one upper floor (one block), owned/occupied by Fair Field, Institute of Management & Technology, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officers concerned of this department on dated 08.11.15 in the presence of Mr. Narender Kumar (Engineer) of the school and found that the building is fit for occupancy class B 'Educational Building' with effect from ...05/02/...2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on ...05/02/...2015 at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333



Copy to,

Sh. V.K.Nangalia, Chairman,  
Fair Field, Institute of Management & Technology,  
FIMT Campus, Kapashera, New Delhi-110037

**Conditions for the validity of fire safety certificate are overleaf:-**

## CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

1. Name & address of the building :Fair Field, Institute of Management & Technology, FIMT Campus, Kapashera, New Delhi-110037.
2. Building is comprised of :B+ G+3(Three blocks), & B+G+1(One block).
3. Type of Occupancy : Education
4. Type of Case : New.
5. Details of Previous NOC : Nil.
6. Fire Safety direction letter No : F.6/DFS/MS/BP/2011/2933, Dated- 09.11.11.
7. Date of Inspection : 08.01.15.
8. Name of the Inspecting Officers: : D.P.Bhardwaj (DO) & Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Narender Kumar (Engineer).
10. Year of Construction : 2012.
11. Applicant's letter No : FIMT/admn/DFS-NOC/2014-15, dated 23.12.14.

S.No	Minimum Standards on fire prevention and fire safety as per Rules.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	9 m	MR
	Gate width	5m	5m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	1no.in A Block, 02 nos. in B Block, 02nos. in C Block & 02nos. in Cafeteria Block.	1no.in A Block, 03 nos. in B Block, 02nos. in C Block & 02nos. in Cafeteria Block.	MR
	Basement	1no.in A Block, 02 nos. in B Block, 02nos. in C Block & 02nos. in Cafeteria Block.	1no.in A Block, 02 nos. in B Block, 02nos. in C Block & 02nos. in Cafeteria Block+1ramp for A& B Blocks.	MR
	B. Width of Staircases			
	Upper Floor	1.5 m (each)/90cm	A&B Block=1.27m, 1.5,1.7&1m C Block 1.4&1.5m Cafeteria Block 1&1.5m.	MR
	Basement	1.5m (each)/90cm	A=1.27m&1ramp1.7m, B=1.5& 1m & ramp common, C=1.4m & 1.5m, Cafeteria Block=1&1.5m.	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	1no. in each block	Provided	MR
	h. Door Size			
	1.5 m	1.5 m	MR	
	1 m	1m	MR	
3	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.

	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fan Provided	MR
	Upper floor	12 a/c per hour	N.A.	N.A.
5.	Fire Extinguisher			
	Total numbers	36nos.	40nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor in each block	1 no.	1 no.	MR.
	Length of hose reel hose	30m	Provided	MR.
	Nozzle diameter	5cm	Provided	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	stage of auditorium	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of down-comer	N.A.	100mm.	N.A.
	Number of hydrants on each floor in Each block	N.A.	01no.	N.A.
	Hose Box	N.A.	01no.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2280lpm	2280lpm	MR
	➤ Head of Main Pump	40m	40m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	40m	40m	MR
	➤ Standby pump out put	2280lpm	2280lpm	MR
	➤ Standby pump Head	40m	40m	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	➤ Terrace Level	01no.on two blocks	01no. each on two blocks.	MR.
	➤ Discharge of pump	900lpm	900lpm	MR.
	➤ Head of the Pump	40m	40m	MR.
	➤ Power supply	Required	Provided	MR.

Captive Water Storage for Fire Fighting.

	Underground tank capacity	50000liters.	50000liters.	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	15000 liters each on two blocks	15000liters each on two blocks	MR.
15	Exit Signage.	Required	Provided	MR.
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for kind consideration please.

Signature of the Inspecting Officer  
Name: D.P.Bhardwaj

Designation Divisional Officer

Signature of the Inspecting Officer  
Name: Vedpal

Designation Assistant Divisional Officer