

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593


No.F.6/DFS/MS/School/2015/ 52 / 207

Dated: 11 / 02 / 15

FIRE SAFETY CERTIFICATE

Certified that the building of **Bapu Adarsh Vidyalaya (Sec.)** located at R-Block, New Rajinder Nagar, New Delhi-110060. The building is comprised of ground floor plus one upper floor but the school is running at ground floor only was issued NOC by this department vide letter No.F.6/DFS/MS/School/2011/2732 dated 28.10.2011 for ground floor plus one upper floor. The School building was re- inspected by the officer concerned of this department on 04.02.2015 in the presence of Smt. Asha Kadam (Vice Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (**Ground floor only**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....11...../02/15.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Ph:- 011-23414333

Copy to:-

1. The Vice Principal,
Bapu Adarsh Vidyalaya (Sec.),
R-Block, New Rajinder Nagar, New Delhi-110060.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

The building is comprised of Ground Floor Plus one Upper Floor
 Note:- The school is running at Ground Floor only.

M/G.

INSPECTION REPORT

1. Name & address of the building: Bapu Adrash Vidyalaya Sec. R-Block, Near Rajinder Ngr, N.D-60
2. Type of Occupancy: Educational (School)
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. F.C/DFS/MS/School/2011/2732 Dated 28.10.2011
5. Fire Safety directives letter No: —
6. Date of inspection: 04.02.2015
7. Name of Inspecting Officer: A.D.O P.S. Dahiya
8. Name and designation of officers:
 From the building side: Smt. Asha Kadam (Principal)
9. Year of Construction: Before 1980
10. Applicant's letter No.: BAV/2013-2014/268 dated

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	09 mtr	MR
	• Gate width	—	340 cms	MR
	• Width of internal road	—	—	—
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	—	—	School running at Ground floor only.
	• Basements	—	—	NO Basement
	b. Width of staircases			
	• Upper Floor	—	—	School running at Ground floor only.
	• Basements	—	—	NO Basement
	c. Protection of exits			
	• Fire check door	—	—	—
	• pressurization	—	—	—
	d. No. of continuous staircases to terrace	—	—	—
	e. Width of Corridor	—	—	—
	f. Door Size	—	95 cms x 205 cms	—
3.	Compartmentation			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System			
	• Basements	30 a/c per hour	—	NO Basement
	• Upper floors		Natural Ventilation	MR

N/10

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<p>04 Nos ABC ISI marked</p>	<p>Provided - do - ISI Marked</p>	<p>MR MR MR</p>
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>- 30 m 5 mm</p>	<p>- - -</p>	<p>- - -</p>
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	<p>- - - - -</p>	<p>- - - - -</p>	<p>- - - - -</p>
8.	MOEFA		-	-
9.	Public Address System		-	-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	<p>- - -</p>	<p>- - -</p>	<p>No Basement - -</p>
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>- - -</p>	<p>- - -</p>	<p>- - -</p>
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	<p>- -</p>	<p>- -</p>	<p>- -</p>
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	<p>- - - - - - - -</p>	<p>- - - - - - -</p>	<p>- - - - - - -</p>

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
15.	Exit Signage.	<i>Required</i>	<i>Provided</i>	<i>MR</i>
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	<i>No Lift</i>
		-	-	<i>-do-</i>
		-	-	<i>-do-</i>
		-	-	<i>-do-</i>
17.	Standby power supply	-	-	-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2011/2732 dated 28.10.2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- The building is comprised of Ground floor plus one upper floor. Some portion of the building with staircase demolished. The school is running at Ground floor only as per letter submitted by the Vice-Principal of the school. FSC is recommended to run the school at ground floor only.


Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation