

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS; DELHI FIRE SERVICE, NEW DELHI-110001.

No.F6/DFS/MS/Mercantile/2015/SZ /197

Dated: 10/02/15

FIRE SAFETY CERTIFICATE

Certified that the EROS Metro Mall, Plot No.8, Sector-14, Dwarka, Delhi-110075, comprised of two basements, lower ground, ground plus three upper floors was granted NOC by this department vide letter no. DFS/MS/2011/ 1228 dated 15.6.2011. The building was reinspected by the officers concerned of this department on 17.1.2015 in presence of Sh. Omparkash (Asst.Manager) & Sh. Jitender (Fire Technician) and found that the building have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy "Mercantile building" with effect from ...10/02/15..... for a period of **Three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed overleaf.

Issued on ...10/02/15..... at New Delhi by



(Dr. GC Misra)

Chief Fire Officer

Ph.011-23414333

Copy to:

1. Authorized signatory, M/S Eros Metro Mall, 8<sup>th</sup> floor, Eros Corporate Tower, Nehru Place, New Delhi-110019.



## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with a copy of the certificate, six months prior to its expiry.

1	Name & address of the building	
2	Type of Occupancy	Mercantile
3	Type of case	Renewal
4	Details of previous NOC	F6/DFS/MS/2011/1228 Dated. 15.6.2011
5	Fire safety directives letter No	F6/DFS/MS/BP/2008/2140 Dated 28.7.2008
6	Date of inspection	17.1.2015
7	Name of the inspecting Officers :	DO Sanjay tomar & ADO Satpal Bhardwaj
8	Name and designation of officers from the building side	Sh.Omparkash (Asst. Manager) & Sh. Jitender (Fire Technician)
9	Year of construction	2011
10	Applicant's letter No.	Nil 12.12.2014

**Two Basement, Lower Ground, Ground + Three upper Floors**

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			MR
	1) Road width	9 Meters	20 Meters	MR
	2) Gate width	6 Meters	6 Meters	MR
	3) Width of internal road	6 Meters	6 Meters	MR
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	5 Mnos.	5 Nos.	MR
	2. basements	6 Nos.	6 Nos.	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.25 Meters	1.25 Meters	MR
	2. basements	1.25 Meters	1.25 Mtrs.+2 Ramps 4.5 Mtrs.	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	<b>d. No. of continuous staircase to terrace</b>			
		2 Nos.	2 Nos.	MR
	<b>e. Width of corridor</b>			
		1.75 Mtrs.	1.75 Mtrs.	MR
	<b>f. Door size</b>			
		1.45 Mtrs.	1.45 Mtrs.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	Required	Provided	MR
	4. water curtain	Required	Provided	MR
	5. Fire dampers	Required	Provided	MR
<b>4</b>	<b>Smoke Management system.</b>			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	40 Nos.	40 Nos.	MR
	Types	Co2 & ABC	Co2 & ABC	MR
	ISI marking	Required	Provided	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	4 Nos.	4 Nos.	MR
	Length of Hose reel hose	30 M	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	Smoke / Heat	Provided	MR
	location of Main Panel	Control Room	Control room	MR
	location of Repeater panel	Lower ground floor	Provided	MR
	Alternate source of power	Required	Battery Backup	MR
	hooter's location	Appropriate Places	Provided	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System.</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	150 mm	200 mm	MR
	Number of Hydrants per floor	4 Nos.	04 Nos.	MR
	hose Box	Required	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	6 Nos.	6 Nos.	MR
	hose box	Required	Provided	MR
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	2850 LPM	2850 LPM	MR
	b. Head of main pump	70 M	70 M	MR
	c. Number of main pumps	2 Nos.	2 Nos.	MR
	d. jockey pump out put	2 X 180 LPM	2 X 180 LPM	MR
	e. jockey pump head	70 M	70 M	MR
	f. Standby Pump output	2850 LPM	2850 LPM	MR
	g. Stanby Pump head	75 Mtrs.	75 M	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	l. pump house access	Required	Provided	MR
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	At ground level	1,00,000 Ltrs.	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	25000 Lts.	25000 Lts.	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	Required	Prvided	MR
	b. pressurization of lift lobby	Required	Provided	MR
	c. communication in lift car	Required	Prvided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
<b>17</b>	<b>Standby power supply</b>	Required	DG Set 600 KVA	MR

18	<b>Refuge Area.</b>			
			N/A	N/A
	total area			
	location	N/A	N/A	N/A
19	<b>Fire control room</b>			
	a. Detector system Panel	Required	Provided	MR
	b. Flow switch Panel	Required	Provided	MR
	c. PA system Panel	Required	Provided	MR
	d. Battery backup	Required	Provided	MR
	e. Building floor plans	Required	Provided	MR
20	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	<b>Co2 system Provided.</b>		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of Fire Safety Certificate issued vide letter no.F6/DFS/MS/2011/1228 dated 15.6.2011 is recommended under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer

Name Sanjay Tomer  
 Designation DO (South West)

  
 Signature of the Inspecting Officer

Name S.P. Bhardwaj  
 Designation ADO (Dwarka)