

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/dfs/ms/school/2015/w2/202

Dated: 11 / 02 / 2015

FIRE SAFETY CERTIFICATE

Certified that **Jai Hind International School, 48/20, Krishna Nagar Colony, Singhu Border Road, Narela, Delhi-110040** comprised of **Ground floor Only** owned / occupied by **Jai Hind International School** have complied with fire prevention & fire safety requirement in accordance with the **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and verified by the officer concerned of Fire Service on **21/01/2015** in the presence of **Sh. Jagdish Kumar (Principal)** and that the building / premises is fit for occupancy of **Group Class B (Educational)** with effect from 11 / 02 / 2015 for a period of **three years**, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 11/02/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Jai Hind International School, 48/20, Krishna Nagar Colony, Singhu Border Road, Narela, Delhi-110040
2. The Director of Education, Old Secretariat, Delhi

G.N. floor only.

INSPECTION REPORT

1. Name & address of the building : Jai Hind International School, 48/20
2. Type of Occupancy : Educational Krishna Colony, Singha B
3. Type of Case : New Case/ Renewal Narela Delhi-40
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : Dir of Edu. CR - 01.3.2011 ✓
6. Date of inspection : 21.1.15
7. Name of the Inspecting Officers : ADP(B10)
8. Name and designation of officers from the building side : Sh. Jagdish Kumar Principal
9. Year of Construction : 2009
10. Applicant's letter No. : N/A dt. 9.12.14

Plot Area: 955 sq. yards Covered Area: 398 sq. yard. No. of Students: 138 No. of Class Rooms: 6 ✓
one office.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR	
1	Access to building				
	• Road width	<u>Accessable</u>	<u>Accessable</u>	<u>MR</u>	
	• Gate width	<u>—</u>	<u>—</u>	<u>—</u>	
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>	
2	Number, Width, Type & Arrangement of Exits				
	a. Number of staircases			/	
	• Upper Floors				
	• Basements				
	b. Width of staircases				
	• Upper Floors				
	• Basements				
	c. Protection of exits				
	• Fire check door				
	• Pressurization				
	e. No. of continuous staircases to terrace				
	g. Width of Corridor				
	h. Door Size	<u>1.00 m²</u>	<u>1.00 m² Double Doors</u>		<u>MR</u>

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour			
		12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	304	5	MR	
		ISI marked	ABC	MR	
			yes	MR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m			
		5 mm			
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 				

Jun Heer and Educational School
 48/20 Kirti Colony Gurgaon
 Narela Delhi-40

12	Yard Hydrants.	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.				
16	Provision of Lifts.	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply				

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

Note:- General requirements for school as per Director of Education Circular dated...../...../.....

1. Escape route..... clear
2. LPG cylinders in laboratories NIL
3. Electric wiring Conduct MCB and ELCB
- Electric circuit..... —
4. Electric meter board Not below 5/c
5. Basement use as per BBL 1983..... NIL
6. Emergency telephone no. board..... displayed
7. Generator set..... NO

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... NIL

Signature of the Inspecting Officer

Name

Designation

DO (H/O) Gupta

Signature of the Inspecting Officer

Name

Designation

h h dan
25.1.15
ADCO (A)

