

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2015/22/220

Dated: 11 / 2 / 2015

FIRE SAFETY CERTIFICATE

Certified that **Murti Devi Public School, A-2 Block-221, Sant Nagar, Burari, Delhi-110084** comprised of **Ground + Two upper Floor** owned/occupied by **Murti Devi Public School** has already been issued fire safety Certificate vide letter **No F-6/MS/DFS/2006/3462 dated 30/11/2006**. The premise was re-inspected by the officer have deem complied with the fire prevention and fire safety requirements in accordance with **circular no. 262-362 at 17/01/05 issued by Director of Education** and verified by the officer concerned of Fire Service on **14/01/2015** in the presence of **Sh. Ram Shankar Singh (Chairman)** and that the building is fit for occupancy of **Group Class B (Educational)** with effect from **..!!..../2015** for a period of **Three years** subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 11/02/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250


Copy to:

1. The Principal, Murti Devi Public School, A-2 Block-221, Sant Nagar, Burari, Delhi-84
2. The Director of Education, Old Secretariat, Delhi

Gr. + 1st 2002

INSPECTION REPORT

1. Name & address of the building : Murthi Devi Public School, A-221, A-2 Block
2. Type of Occupancy : Educational Bhagal Colony
3. Type of Case : New Case/ Renewal West Samf Nagar
4. Details of previous NOC : Letter No. F-6/MS/DFS/2006/3462 Dated: 30.11.06 Barari Delhi-89
5. Fire Safety directives letter No : Dir. of Edu. Cir. 17.01.05
6. Date of inspection : 14.1.15
7. Name of the Inspecting Officers : A 20 (BW)
8. Name and designation of officers from the building side : Sh. Ravi Shankar Singh - Chairman
9. Year of Construction : 2005
10. Applicant's letter No. : Mic Lt. 21.11.14

Plot Area: 2100sqm² Covered Area: 1728sqm² No. of Students: 622 No. of Class Rooms: 21
2 office.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessable</u>	<u>Accessable</u>	<u>MR ✓</u>
	• Gate width	<u>—</u>	<u>—</u>	<u>—</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>02</u>	<u>02</u>	<u>MR ✓</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	b. Width of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>old case</u>	<u>old case</u>	<u>old case ✓</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>R</u>	<u>P</u>	<u>MR ✓</u>
	g. Width of Corridor	<u>—</u>	<u>—</u>	<u>—</u>
	h. Door Size	<u>old case</u>	<u>old case</u>	<u>old case ✓</u>

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	7 ABC ISI marked	7 ABC Yes	MR MR MR	✓ ✓ ✓
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	D P P	MR MR MR	✓ ✓ ✓
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer ✓ • Number of hydrants per floor one • Hose Box 	R R R	P P P	MR MR MR	✓ ✓ ✓

12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		N/A		
		450 LPM	P	MR ✓
		40 M	P	MR ✓
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 			
		N/A		
		5000 lts	P	MR ✓
15	Exit Signage.	R	P	MR ✓
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 			
		N/A		
17	Standby power supply			

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

Note:-General requirements for school as per Director of Education Circular dated 17.1.01...1.05

1. Escape route..... clear.....
2. LPG cylinders in laboratories NO.....
3. Electric wiring concealed..... MCB and ELCB ✓
- Electric circuit..... ✓
4. Electric meter board below 5/2 but covered with metal B-plate.....
5. Basement use as per BBL 1983..... N/A.....
6. Emergency telephone no. board..... displayed.....
7. Generator set..... NO.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F-6/M.S/D.F.S/2006/3462 dated 29.11.06 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
[Handwritten Signature]

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
221115
ADD(BW)

