

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2015/W2/201

Dated: 11 / 02 / 2015

FIRE SAFETY CERTIFICATE

Certified that P M Public School, 678, Jeewan Park, Siraspur, Delhi – 110042 comprised of Ground + One Upper Floor owned/occupied by P M Public School, has already been issued fire safety certificate vide letter no.F-6/MS/DFS/2007/727 dated 13/03/2007. The premises was re-inspected by the officer have deem complied with the fire prevention and fire safety requirements in accordance with circular no. 262-362 at 17/01/2005 issued by Director of Education and verified by the officer concerned of Fire Service on 14/01/2015 in the presence of Sh. Surender Rana [Chairman] and that the building is fit for occupancy of Group Class B (Educational) with effect from 11 / 02 / 2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 11/02/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:-

1. The Principal, P M Public School, 678, Jeewan Park, Siraspur, Delhi – 110042
2. The Director of Education, Old Secretariat, Delhi

Gr. + one floor

INSPECTION REPORT

1. Name & address of the building : P.M. Public School, 678/1, Teewan Park
2. Type of Occupancy : Educational Siraspur delhi 42
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/MS/DFS/2007/727 Dated: 13.3.07
5. Fire Safety directives letter No : Dir. of Edu. Cir. 17-01-05
6. Date of inspection : 14.1.15
7. Name of the Inspecting Officers : ASO (B.W)
8. Name and designation of officers from the building side : Ch. Sureshwar Rang chairman
9. Year of Construction : 2002
10. Applicant's letter No. : Dec-2014/46 Dt. 12.11.14

Plot Area: 1500 Sq. yards Covered Area: 1200 Sq. yards No. of Students: 272 No. of Class Rooms: 8

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessable</u>	<u>Accessable</u>	<u>MR</u> ✓
	• Gate width	<u>-</u>	<u>-</u>	<u>-</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>01</u>	<u>02</u>	<u>MR</u> ✓
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	b. Width of staircases	<u>1.50 mtr</u>	<u>1.50 & 0.80 mtr</u>	<u>MR</u> ✓
	• Upper Floors	<u>-</u>	<u>-</u>	<u>-</u>
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	c. Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	e. No. of continuous staircases to terrace	<u>-</u>	<u>-</u>	<u>-</u>
	g. Width of Corridor	<u>-</u>	<u>-</u>	<u>-</u>
	h. Door Size	<u>1 mtr</u>	<u>1.10 mtr</u>	<u>MR</u> ✓

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour			
		12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	5 ABC ISI marked	5 ABC 400	MR MR MR	/
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one R 30 m 5 mm	P P P	MR MR MR	/
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 				

N/A

N/A

N/A

12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		N/A		
		220 LPM	P	MR ✓
		40 M	P	MR ✓
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 			
		N/A		
		2500 Lts	P	MR ✓
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 			
		N/A		
17	Standby power supply			

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

Note:- General requirements for school as per Director of Education Circular dated 12/01/05

1. Escape route..... Clear
2. LPG cylinders in laboratories N/A
3. Electric wiring Concealed MCB and ELCB
- Electric circuit.....
4. Electric meter board Not below 9L
5. Basement use as per BBL 1983..... N/A
6. Emergency telephone no. board..... Not displayed
7. Generator set..... N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DOF/2007/725 dated 12/03/07 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

Handwritten signature
22/1/15

ADO (B)

