

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593


No: F.6/DFS/MS/School/2015/ 52 /209

Dated: 11/02/15

FIRE SAFETY CERTIFICATE

Certified that the building of **Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya**, New Rajinder Nagar, New Delhi -110060 is comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/School/2011/2833 dated 03.11.2011. The School building was re-inspected by the officer concerned of this department on 04.02.2015 in the presence of Sh. Prem Sukh (Principal) and found that the school management (Govt. of NCT of Delhi) have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on11/02/15.....at New Delhi



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Ph:- 011-23414333

Copy to: -

1. The Principal,
Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya,
New Rajinder Nagar, New Delhi -110060.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Ground Floor Plus One Upper Floor

N/7

INSPECTION REPORT

1. Name & address of the building: Rana Pratap Govt. (Sindhi) Sarvodaya Vidya
2. Type of Occupancy: Educational (School) New Rajinder Nagar
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. F.6/DFS/MS/School/2011/2839 Dated 03.11.2011
5. Fire Safety directives letter No: -
6. Date of inspection: 04.02.2015
7. Name of Inspecting Officer: A.D.O P.S. Nahiya
8. Name and designation of officers
From the building side: Sh. Prem Sukh (Principal)
9. Year of Construction: Before 1960
10. Applicant's letter No.: RPSV/NRN/15/365 dated 22.01.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	09mtr	MR
	• Gate width	-	350 cms	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	MR
	• Basements	-	-	No Basement
	b. Width of staircases			
	• Upper Floor	-	140cms Each	MR
	• Basements	-	-	No Basement
	c. Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
	d. No. of continuous staircases to terrace	-	One	-
	e. Width of Corridor	-	240 cms	-
	f. Door Size	-	104cms x 210cms	-
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR

N/8

		12 a/c per hour	-	-
Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	10 Nos ABC ISI marked	Provided - do - ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	- 30 m 5 mm	- - -	- - -
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	- - - - -	- - - - -	- - - - -
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	- - -	- - -	No Basement - -
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	- - -	- - -	- - -
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- -	- -	- -
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	- - - - - - - -	- - - - - - -	- - - - - - -

11

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
15.	Exit Signage.	<i>Required</i>	<i>Provided</i>	<i>MR</i>
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	<i>No Lift</i>
		-	-	<i>- do -</i>
		-	-	<i>- do -</i>
		-	-	<i>- do -</i>
17.	Standby power supply	-	-	-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

N/10,

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.G/DFS/MS/School/2011/2833 dated 03.11.2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation