

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: cfhq.dfire@nic.in


No.F6/DFS/MS/2015 / MD2 / 239

Dated 18/02/15

FIRE SAFETY CERTIFICATE

Certified that the **Bhai Vir Singh Sahitya Sadan** located at **Bhai Vir Singh Marg, Gole Market, New Delhi** comprises of **Basement + Ground + 3 upper floor** was granted NOC by this department vide letter **No.F6/DFS/MS/2011/160 dated 27-01-2011**. The premises was re-inspected by the officer concerned of this department on 29-01-2015 in the presence of Sh. Paramjit Singh Astt. Dir. and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Sub Division E-2 Laboratories, Research, Establishment, Libraries and Test House of Group E Business Building** for with effect from ~~18/02/2014~~ 18/02/2015 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/02/15 at New Delhi by.


(**Dr.G.C. Misra**)
Chief Fire Officer
Ph – 011-23414333

Copy to:-

1. Sh. Paramjit Singh Astt. Dir. Bhai Vir Singh Sahitya Sadan at Bhai Vir Singh Margh, Gole Market, Dew Delhi.
2. Chief Architect, NDMC

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

N/16

INSPECTION REPORT

1. Name & address of the building : Bhai Vir Singh Sadan located at Bhai Vir Singh Marg, Gole Market, New Delhi.
2. Type of Occupancy : Business Building Basement + Ground + 3 upper floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/160 dated 27/01/2011
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2001/2734 dated 24/12/2001
- 6 Date of inspection : 29/01/2015
- 7 Name of the Inspecting Officer : Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer
from the building side : Sh. Paramjit Singh Astt. Dir.
- 9 Year of Construction : Old Building
10. Applicant's letter No. : No. BVSSS/2014/847 dated 25/11/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mtr.	12 Mtr.	MR
	• Gate width	6 Mtr.	6 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 Mtr.	1.6 mt. & 1.20 mt. each	MR
	Basements	1.5 Mtr.	1.70 & 2.0 mtr.	NA
	c..Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

h

mer

N/17

	d. No of continuous staircase to terrace	02	02	MR
	e. Width Of Corridor	1.0 mtr.	1.5 mtr.	MR
	f. Door Size	1.0 mtr.	1.5 mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	40 Nos.	40 Nos.	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	Requried	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Requried	Provided	MR
9	Public Address System	Requried	Provided	MR
10	Automatic Sprinkler			
	• Basements	Requried	Provided	MR
	• Ground Upper Floor	NA	NA	NA

h

Man

N/18

	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	01	01	MR
	<ul style="list-style-type: none"> • Hose Box 	01	01	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> ○ Ground Level • Discharge of main pump • Head of main pump • Number of main pumps • Jockey pump out put • Jockey pump head • Standby Pump out put • Standby Pump Head • auto Staring/Manual stopping • Pump House Access ○ Terrace level • Discharge of pump • Head of the pump • Power supply • Auto starting of pump 			
		1620 LPM	1620 LPM	MR
		56 Mtr.	56 Mtr.	MR
		01	01	MR
		180 LPM	180 LPM	MR
		56Mtr.	56Mtr.	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 LPM	900 LPM	MR
		56 mt	56 mt	MR
		Requried	Provided	MR
		Requried	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity 	50,000 ltr.	60,000 ltr.	MR
	<ul style="list-style-type: none"> • Draw of connection 	Requried	Provided	MR
	<ul style="list-style-type: none"> • Fire service inlet 	Requried	Provided	MR
	<ul style="list-style-type: none"> • Access to tank 	Requried	Provided	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage	Requried	Provided	MR

A

Ma

N/19

16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	CO ₂ & DCP	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/160 dated 27/01/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.



DO (ED)

Submitted by

12/2/15

Signature of the Inspecting Officer

M.K. Sharma
10/1/15

Name :- M.K. Sharma

Designation :- A. D.O. (CC)