

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No.F.6/DFS/MS/School/2015/ 82/236

Dated: 18/02/15

FIRE SAFETY CERTIFICATE

Certified that the building of **Gayatri public school**, Jharoda Kalan, New Delhi-110072, is comprised of ground plus one upper floor, but school is running at ground floor only. School at ground floor was issued Fire Safety Certificate by this department vide letter No F6/MS/DFS/06/2300 dated 04.09.2006. The School building was re- inspected by the officer concerned of this department on 11.02.2015 in the presence of Sh. Suresh Kumar (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (**Ground Floor Only**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....18/02/15..... at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
Ph.: 011-23414333

Copy to:-

1. The Manager,
Gayatri public school, Jharoda Kalan, New Delhi-110072.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

O/C Sam
17/2/15

N/4

Ground floor plus one upper floor, but school running at ground floor only
(Gayatri public school, Jharoda Kalan, New Delhi-110072)

INSPECTION REPORT

1. Name & address of the building : Gayatri public school, Jharoda Kalan, New Delhi-110072.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/MS/DFS/06/2300 dated 04.09.2006
5. Fire Safety directives letter No : N/A
6. Date of inspection : 11.02.2015
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Suresh Kumar (Manager)
9. Year of Construction : 2006.
10. Applicant's letter No. : Letter No. Nil dated 04.02.2015

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Edu. Circular dt. 01.03.2011 | Provided at site | Remarks MR/NMR |
|-----------|---|--|--|--|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <p>Accessible</p> <p>—</p> <p>—</p> | <p>08 mtrs</p> <p>3.20 mtrs.</p> <p>—</p> | <p>M/R</p> <p>—</p> <p>—</p> |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | <p>01</p> <p>N/A</p> | <p>02</p> <p>N/A</p> | <p>M/R</p> <p>No basement</p> |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | <p>—</p> | <p>140 to 130 cms & 94 cms</p> | <p>M/R</p> |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> | <p>N/A</p> <p>N/A</p> | <p>No basement</p> <p>N/A</p> <p>N/A</p> |
| | d. No. of continuous staircases to terrace | | | |
| | | N/A | N/A | N/A |
| | e. Width of Corridor | | | |
| | | N/A | N/A | N/A |
| | f. Door Size | | | |
| | | 100 cms | 90 to 105 cms | M/R, ground floor is old Bldg. Students are less than 45 in each class |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> | <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> | <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements | N/A | N/A | No basement |

SPM

N/S

Ground floor plus one upper floor, but school running at ground floor only
(Gayatri public school, Jharoda Kalan, New Delhi-110072)

| | • Upper floors | N/A | N/A | Ground Floor Only |
|------------|---|------------|------------|-------------------|
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 04 no's | Provided | M/R |
| | • Types | ABC type | Provided | M/R |
| | • IS marking | ISI marked | ISI marked | M/R |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | N/A | N/A |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | • Ground Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head. | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |

2/6

Ground floor plus one upper floor, but school running at ground floor only
(Gayatri public school, Jharoda Kalan, New Delhi-110072)

| | | | | |
|------------|--|----------------|-----|-----|
| | ➤ Auto Starting/Manual Stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | N/A | N/A | N/A |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the pump | N/A | N/A | N/A |
| | ➤ Power Supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | N/A | N/A | N/A |
| 15. | Exit Signage. | | | |
| 16. | Provision of Lifts. | No Lift | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | | | |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |

2/7

Ground floor plus one upper floor, but school running at ground floor only
(Gayatri public school, Jharoda Kalan, New Delhi-110072)

| | | | | |
|-----|---|-----|-----|-----|
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |
|-----|---|-----|-----|-----|

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F6/MS/DFS/06/2300 dated 04.09.2006 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note : As per the letter submitted by the principal of the school (Placed at C-11), the school is running at ground floor only and the number of students in each class is less than 45.

Sandeep
13/2/15

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

13/2/15

Signature of Inspecting Officer

Name

Designation

