

e/41

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/2015/W2/240

Dated: 19/02/15

FIRE SAFETY CERTIFICATE

Certified that the **Happy Hours Primary School**, located at **Zone H -4, Pitam Pura, Delhi - 110034**, comprised of Basement, Ground & 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2011/1886 Dated 05-08-2011. The premises was re inspected by the officer concerned of this department on 13-01-2015 in the presence of Sh. R K sharma (Estate Officer) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262 - 362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 19/02/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 19/02/15 ... at New Delhi by.


(Sh. Santokh Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:

The Principal, Happy Hours Primary School, Zone H -4, Pitam Pura, Delhi - 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/15

INSPECTION REPORT

1. Name & address of the building: Happy Hours Primary School, Zone H -4, Pitam Pura, Delhi – 110034
2. Type of Occupancy : Educational (Basement + Ground + 2Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/1886 Dated 05-08-2011
5. Fire Safety directives Letter No. : DOE Circular 262-362 Dated 17/01/2005
6. Date of inspection : 13-01-2015
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : SH.RK Sharma (Estate Manager)
9. Year of Construction : 1991
- 10.
11. Applicant's letter No. : Letter no.HHS Dated 09-12-2014

No. of Students=600
No. of class rooms=15
Plot area=7893m ²
Covered area=390 m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	Circular no.262-362 dt.17/01/05	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	Old Case	Old Case	Old Case
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided 1x1.25m 1x97cm	MR
	• Basements	02	Provided 1x1.23m 1x97cm	MR
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	Old Case
	• Basements	Old Case	Old Case	Old Case
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR

	e. Width Of Corridor f. Door Size	Old Case Old Case	Old Case Old Case(students less than 45 in all class)	Old Case Old Case
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided(Exhaust fan provided)	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	08nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100mm	Provided	MR
		01	Provided	MR

N/17

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	01	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		1X450 lpm	Provided	MR
		1X180 lpm		
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000Ltr	Provided	MR
		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply			
		NA	NA	NA

14/12


18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratories ; NA
3. Electric wiring ...canceled Wiring..... MCB and ELCB
.....
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983 ... yes
6. Emergency telephone no. boardDisplayed...
7. Generator set Provided out side the building

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/21886 Dated 05-11-20011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

 Officer

Signature of the Inspecting

Name Uday Vir Singh
 Designation ADO/WP

Name
 Designation

