

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F6/DFS/MS/2015/ 52/250

Dated: 24/02/15

FIRE SAFETY CERTIFICATE

Certified that M/S Ramayana Handicrafts located at E-40/5, Okhla Industrial Area, Phase II, New Delhi-110020 comprised of basement, ground, mezzanine, first & ½ IInd floor, owned/occupied by M/S Ramayana Handicrafts was issued FSC by this department vide letter no F6/DFS/MS/2011/2816 dated 01/11/2011. The premises was re-inspected by the officer concerned of this department on 30/01/2015 in the presence of Mr. Anil Lal and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Industrial Building** with effect from... 24/02/15.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 24/02/15 at New Delhi by


(Dr. G.C. Misra)
Chief Fire Officer
Tel:- 011-23414333

Copy to:-

Mr. Anil Lal,
Executive Officer,
Plot No. E-40/5, Okhla Industrial Area
Phase II, New Delhi-110020

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [subrule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Ramayana Handicrafts, E 40/5, Okhla Industrial Area, Phase-II, New Delhi-110020
2. Type of Occupancy : Group-G (Industrial)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/2816 dated 01/11/2011
5. Fire Safety directives letter No : Nil
6. Date of inspection : 30/01/2015
7. Name of the Inspecting Officers : ADO D.B.Mukherjee
8. Name and designation of officers from the building side: Mr. Anil Lal
9. Year of Construction :1982
10. Applicant's letter No. : Nil, Dtd.: 29/10/2014

(Basement + Ground + Mezzanine floor + First Floor + Half Second Floor)

Sl. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	10 mtrs	Provided	MR
		5 mtrs	Provided	MR
		Not Required	2Mtrs Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02	02	MR
		02	02	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.5 m	1.5 m & 94cm	MR
		1.5 m	1.5 m & 110 cm	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required	Provided	MR
		Required	Provided	MR
	e. No. of continuous staircases to terrace	02 nos	Provided	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust Fans Provided Natural Ventilation	MR MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	ISI marked	30 Nos ABC,Co2 Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required N/A Required Staircase	Provided (Smoke) Provided (Ground Floor) N/A Provided Provided	MR MR N/A MR MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required Required N/A	Provided Provided N/A	MR MR N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm 01 01	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided Provided	MR MR

Pumping Arrangements.

<ul style="list-style-type: none"> • Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access • Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
	2280 LPM	Provided	MR
	70 m	Provided	MR
	01	Provided 01 no	MR
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	Required	Provided	MR
	Required	Provided	MR
	900 LPM	Provided	MR
	40 mtr	Provided	MR
	Required	Provided	MR
	Required	Provided	MR

14 Captive Water Storage for fire fighting.

<ul style="list-style-type: none"> • Underground tank capacity Draw-off connection Fire service inlet Access to tank • Overhead Tank capacity 	100000 Ltrs	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	20000 Ltrs.	Provided	MR

15 Exit Signage. Required Provided MR

16 Provision of Lifts.

<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	Not Required	Not Required	MR
	Not Required	Not Required	MR
	Not Required	Not Required	MR
	Not Required	Not Required	MR
	Not Required	Not Required	MR

17 Standby power supply Required Provided MR

18 Refuge Area.

➤ Total Area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A

N/7

19	Fire Control Room	Required	Provided	MR
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	Not Required	Not Required	MR
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/2816 Dated:01/11/2011 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.


17/2/14

Signature of the inspecting officer

Name:-D.B.Mukherjee.

Designation:- Assistant Divisional Officer (BCP)


(Contd.)


17/2/15