

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**


No.F6/MS/DFS/Hospital/2015/ 52/288

Dated: 27/02/2015

FIRE SAFETY CERTIFICATE

Certified that Max Super Specialty Hospital at Plot No. -1, Press Enclave Road, Saket, New Delhi-110017, comprised of 2 tire basements, ground & 06 upper floors, was granted NOC by this department vide letter No.F6/DFS/MS/Hospital/2008/684 dated 07/03/2008. The premises was re-inspected by the officer concerned of this department on 19/02/2015 in the presence of Sh. Deepak. Fansal (Chief Engineer) and Sh. Arjun Rawat (Fire Officer) and found that the Hospital deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group-C, Institutional Building(Hospital)** with effect from ~~27/02/15~~ ^{27/02/15} for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 subject to conditions as mentioned below.

Issued ~~27/02/15~~ at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Tel: 011-23414333

9c [Handwritten initials]

Copy to:-

The Authorized Signatory
Plot No. -1, Press Enclave Road, Saket,
New Delhi-110017

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORTS

1	Name & address of the building	Max Super Specialty Hospital at Plot No. 1, Press Enclave Road, Saket, New Delhi-110017		
2	Type of Occupancy	Institutional building "G" (Hospital)		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/Hospital/2008/684 dated 07.03.2008		
5	Fire safety directives letter No	F6/DFS/MS/BP/Hospital/2004/1986 dated 02.09.2004 & No. 465 Dated 23.02.200		
6	Date of inspection	19.02.2015		
7	Name of the inspecting Officers	DCFO Atul Garg, DO Dharampal Bhardwaj & ADO D.B. Mukherjee		
8	Name and designation of officers from the building side	Sh. Deepak Fansal and Sh. Arjun Rawat (Fire Officer)		
9	Year of construction	2008-09		Two tier basement, ground plus six upper floors
10	Applicant's letter No.	Nil	30.01.2015	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9	Provided	MR
	2) Gate width	5 Mtr	Provided	MR
	3) Width of internal road	6 Mtr	Provided	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4	4 Nos Provided	MR
	2. basements	4+ 1 Ramp	4 Nos Stairs Basement 2 to ground floor & 2 stairs basement 1 to ground floor + 1 Ramp Provided	MR
	b. Width of staircase			
	1. Upper floors	2 Mtr	2 Mtrs each provided	MR
	2. basements	2 Mtr	2 Nos- 2 Mtrs each, 2 Nos. 1.50 Mtrs each & 2 Nos Provided	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	d. No. of continuous staircase to terrace	Required	(Four) Provided	MR
	e. Width of corridor	2 Mtr	Provided	MR
	f. Door size	2 Mtr & 1.5 Mtr	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	Required	Provided	MR
	4. water curtain	Required	Provided	MR
	5. Fire dampers	Required	Provided	MR
4	Smoke Management system.			
	basement	30 a/c per hour	Mech. Ventilation Provided	MR
	upper floors	12 a/c per hour		
5	Fire Extinguishers			
	total numbers		285 Nos. Provided	MR
	Types		ABC, CO2 , Water Co2	MR
	ISI marking	ISI	Provided	MR

INSPECTION REPORTS

6	First-Aid Hose Reels.			
	total numbers on each floor	Four	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Required	Somke/Heat Provided	MR
	location of Main Panel	Required	Basement 1 Provided	MR
	location of Repeater panel	Required	Sectury Control Room Provided	N/A
	Alternate source of power	Required	Battery Backup Provided	MR
	hooter's location	Required	Staircase Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	Size of riser/down-corner	150 MM	Provided	MR
	Number of Hydrants per floor	Four	Provided	MR
	hose Box	Four	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	7 Nos.	Provided	MR
	house box	7 Nos.	Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2850 LPM	Provided	MR
	b.Head of main pump	60 Mtr	Provided	MR
	c.Number of main pumps	Two	Provided	MR
	d.jockey pump out put	180 LPM (Two)	Provided	MR
	e.jockey pump head	60 Mtr	Provided	MR
	f. Standby Pump output	2850 LPM	Provided	MR
	g.Stanby Pump head	60 Mtr	Provided	MR
	h.Auto Starting/Manual stopping	Required	Both Provided	MR
	pump house access	Required	Provided	MR
	2.Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	2,00,000 Ltrs	2,00,000 Ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c.Access to tank	Required	Provided	MR
	Over head tank Capacity	20,000 Ltr	20,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	Required	Provided	MR
	b. pressurization of lift lobby	Required	Provided	MR
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR

INSPECTION REPORTS

1	Name & address of the building	Max Super Specialty Hospital at Plot No. 1, Press Enclave Road, Saket, New Delhi-110017		
2	Type of Occupancy	Institutional building "G" (Hospital)		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/Hospital/2008/684 dated 07.03.2008		
5	Fire safety directives letter No	F6/DFS/MS/BP/Hospital/2004/1986 dated 02.09.2004 & No. 465 Dated 23.02.2005		
6	Date of inspection	19.02.2015		
7	Name of the inspecting Officers :	DCFO Atul Garg, DO Dharampal Bhardwaj & ADO D.B. Mukherjee		
8	Name and designation of officers from the building side	Sh. Deepak Fansal and Sh. Arjun Rawat (Fire Officer)		
9	Year of construction	2008-09		Two tier basement, ground plus six upper floors
10	Applicant's letter No.	Nil	30.01.2015	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9	Provided	MR
	2) Gate width	5 Mtr	Provided	MR
	3) Width of internal road	6 Mtr	Provided	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4	4 Nos Provided	MR
	2. basements	4+ 1 Ramp	4 Nos Stairs Basement 2 to ground floor & 2 stairs basement 1 to ground floor + 1 Ramp Provided	MR
	b. Width of staircase			
	1. Upper floors	2 Mtr	2 Mtrs each provided	MR
	2. basements	2 Mtr	2 Nos- 2 Mtrs each, 2 Nos. 1.50 Mtrs each & 2 Nos Provided	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	d. No. of continuous staircase to terrace	Required	(Four) Provided	MR
	e. Width of corridor	2 Mtr	Provided	MR
	f. Door size	2 Mtr & 1.5 Mtr	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	Required	Provided	MR
	4. water curtain	Required	Provided	MR
	5. Fire dampers	Required	Provided	MR
4	Smoke Management system.			
	basement	30 a/c per hour	Mech. Ventilation Provided	MR
	upper floors	12 a/c per hour		
5	Fire Extinguishers			
	total numbers		285 Nos. Provided	MR
	Types		ABC, CO2 , Water Co2	MR
	ISI marking	ISI	Provided	MR

INSPECTION REPORTS

6	First-Aid Hose Reels.			
	total numbers on each floor	Four	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Required	Somke/Heat Provided	MR
	location of Main Panel	Required	Basement 1 Provided	MR
	location of Repeater panel	Required	Sectury Control Room Provided	N/A
	Alternate source of power	Required	Battery Backup Provided	MR
	hooter's location	Required	Staircase Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	Size of riser/down-corner	150 MM	Provided	MR
	Number of Hydrants per floor	Four	Provided	MR
	hose Box	Four	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	7 Nos.	Provided	MR
	house box	7 Nos.	Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2850 LPM	Provided	MR
	b. Head of main pump	60 Mtr	Provided	MR
	c. Number of main pumps	Two	Provided	MR
	d. jockey pump out put	180 LPM (Two)	Provided	MR
	e. jockey pump head	60 Mtr	Provided	MR
	f. Standby Pump output	2850 LPM	Provided	MR
	g. Stanby Pump head	60 Mtr	Provided	MR
	h. Auto Starting/Manual stopping	Required	Both Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	2,00,000 Ltrs	2,00,000 Ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	20,000 Ltr	20,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	Required	Provided	MR
	b. pressurization of lift lobby	Required	Provided	MR
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR

INSPECTION REPORTS


18	Refuge Area.			
	total area	Old Case	130 Sq Mtr Provided	MR
	location	Old Case	3rd, 4th, 5th, & 6th floors	MR
19	Fire control room			
	a. Detector system Panel	Required	Provided	MR
	b. Flow switch Panel	Required	Provided	MR
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special risks, if any:	Co2 flooding system Provided		

The shortcoming vide letter no. DFS/DO/BCP/2012/677 dated 10.1.2012 has been rectified

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/Hospital/2008/684 dated 07.03.2008** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


Accordingly DFA is put up for your approval and signature please.


24/2/15

Signature of the inspecting officer

Name Atul Garg


Designation : Dy Chief Fire Officer


24/2/15

Signature of the Inspecting Officer

Name : Dharampal Bhardwaj

Designation:- Divisional Officer


24/2/15

Signature of the Inspecting Officer

Name :- D.B. Mukherjee

Designation:- Asst Div. Officer (BCP)