

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/motel/2015/w2/246

Dated: 20/02/2015

**FIRE SAFETY CERTIFICATE**

Certified that **Motel Building Kh. No- 73/15, 72/11, 72/12, 72/13 at village Ali Pur, Delhi 110036** comprised of **Basement + Ground + One Upper Floor** owned / occupied by **Sh Raja Singh** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on **05/02/2015** in the presence of **Sh Raja Singh**, and that the building / premises is fit for occupancy **Class Residential and Assembly Buildings** with effect **20/02/2015** for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The trained fire fighting staff should be available round the clock.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 20/02/2015 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

Copy to:

1. The Assistant Engineer (Building), Municipal Corporation of Delhi, Narela Zone, Zonal Office Building, Narela, Delhi.
2. Sh Raja Singh, Motel Building Kh. No- 73/15, 72/11, 72/12, 72/13 at village Ali Pur, Delhi 110036

Motel Building, Khasra no 73/15, 72/11, 72/12 and 72/73 at Village Ali Pur, Delhi.

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N.A	N.A	N.A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	P	M/R
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	P	M/R
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	30 Water Co2	P	M/R
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	02 DCP / Co2	P	M/R
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	P	M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	02	P	M/R
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	P	M/R
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	P	M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	G.F	P	M/R
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	At strategic location	P	M/R
8	<b>MOEFA</b>	R	P	M/R
9	<b>Public Address System.</b>	R	P	M/R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	—	—	—
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	150 mm Minimum	150 mm	M/R
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	02	P	M/R
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	02	P	M/R



Motel Building, Khasra no 73/15, 72/11, 72/12 and 72/73 at Village Ali Pur, Delhi.

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	06	P	M/R
	• Hose Box	R	P	M/R
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	1620 LPM	2280 LPM	M/R
	➤ Head of Main pump	40 m	P	M/R
	➤ Number of main pumps	1-main, Elec. 1-stand with DG, 1-jockey, 1-terrace pump	P	M/R
	➤ Jockey Pump out put	180 LPM	P	M/R
	➤ Jockey pump head			
	➤ Standby Pump out put	1620 LPM	2280 LPM	M/R
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	R	P	M/R
	➤ Pump House Access	R	P	M/R
	• Terrace level			
	➤ Discharge of pump	N.R	900 LPM	N.R
	➤ Head of the pump	—	—	—
	➤ Power Supply	R	P	M/R
	➤ Auto Starting of pump	R	P	M/R
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	1,00,000 ltr	P	M/R
	➤ Draw-off connection	R	P	M/R
	➤ Fire service inlet	R	P	M/R
	➤ Access to tank	R	P	M/R
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	M/R
15	<b>Exit Signage.</b>	R	P	M/R
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	R	P	M/R
	• Pressurization of Lift lobby	R	P	M/R
	• Communication In lift Car	R	P	M/R
	• Fireman's Grounding Switch	R	P	M/R
	• Lift Signage	R	P	M/R
17	<b>Standby power supply</b>	R	P	M/R

M-5

Motel Building, Khasra no 73/15, 72/11, 72/12 and 72/73 at Village Ali Pur, Delhi.

18	<b>Refuge Area.</b>			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N.A	N.A	N.A
	• Flow Switch Panel	N.A	N.A	N.A
	• PA System Panel	N.A	N.A	N.A
	• Batter backup	N.A	N.A	N.A
	• Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	No special risk at present	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

*Deep (W2)*

Signature of the Inspecting Officer

Name

Designation

*Deep*  
*17/12/15*  
*DD (NW)*

*115/D*