

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/school/2011/989 W.2/ 303

Dated: 05/03/2015

FIRE SAFETY CERTIFICATE

Certified that C. K. Nair Public School, Gandhi Ashram, Narela, Delhi 110040 comprised of Ground Floor owned / occupied by C. K. Nair Public School has already been issued fire safety certificate vide letter no. F.6/DFS/MS/2011/989 Dated 26/05/2011. The premises was re-inspected by the officer from this department on dated 02/02/2015 in the presence of Sh. Ashok Kumar (Manager) and observed that the premises have complied with fire prevention and fire safety requirement in accordance with the Circular no 262-362 dated 17/01/2005 issued by Director of Education. The premise is fit for occupancy of Group Class B (Educational) with effect from 05/03/2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 05/03 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, C. K. Nair Public School, Gandhi Ashram, Narela, Delhi 110040
2. The Director of Education, Old Secretariat, Delhi



INSPECTION REPORT

64. + look only

1. Name & address of the building : C.K. Nair Public School, Gandhi Ashram, Narela-40
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/2011/989 Dated: 26/05/2011
5. Fire Safety directives letter No : Dir of Edu Cir 01/03/2011
6. Date of inspection : 02/02/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Sh Ashok Kumar (Manager)
9. Year of Construction : 1983
10. Applicant's letter No. : C.K.N.P.S/1/15 Dated 13/01/2015

Plote Area-800 ~~sq~~ yard Covered Area-200 ~~sq~~ yards No. of students:-210 No's of classrooms:-5
4 Room for other purpose

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessable	Accessable	M/R
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1.00 mtr	1.00 mtr	M/R

3	Compartmentation.			-	-	-
	• Fire check door			-	-	-
	• Sealing of electrical shafts			-	-	-
	• Fire Rating of shaft door			-	-	-
	• Water Curtain			-	-	-
	• Fire Dampers			-	-	-
4	Smoke Management System.					
	• Basements	30 a/c per hour		-	-	-
	• Upper floors	12 a/c per hour		-	-	-
5	Fire Extinguishers					
	• Total numbers	3ABC		3	M/R	
	• Types	ISI marked		ABC	M/R	
	• IS marking			Yes	M/R	
6	First-Aid Hose Reels.					
	• Total numbers on each floor			-	-	-
	• Length of hose reel hose	30 m		-	-	-
	• Nozzle diameter	5 mm		-	-	-
7	Automatic fire detection and alarming system.					
	• Type of detectors			-	-	-
	• Location of Main Panel			-	-	-
	• Location of Repeater Panel			-	-	-
	• Alternate source of power			-	-	-
	• Hooters' Location			-	-	-
8	MOEFA					
				-	-	-
9	Public Address System.					
				-	-	-
10	Automatic Sprinkler System.					
	• Basement			-	-	-
	• Upper Floor			-	-	-
	• Sprinkler above false ceiling			-	-	-
11	Internal Hydrants					
	• Size of riser/down-comer			-	-	-
	• Number of hydrants per floor			-	-	-
	• Hose Box			-	-	-

12	Yard Hydrants.		
	• Total number of hydrants	-	-
	• Hose Box	-	-
13	Pumping Arrangements.		
	• Ground Level	-	-
	➤ Discharge of main Pump	-	-
	➤ Head of Main pump	-	-
	➤ Number of main pumps	-	-
	➤ Jockey Pump out put	-	-
	➤ Jockey pump head	-	-
	➤ Standby Pump out put	-	-
	➤ Standby Pump Head	-	-
	➤ Auto Starting/ Manual stopping	-	-
	➤ Pump House Access	-	-
	• Terrace level	-	-
	➤ Discharge of pump	-	-
	➤ Head of the pump	-	-
	➤ Power Supply	-	-
	➤ Auto Starting of pump	-	-
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	-	-
	➤ Draw-off connection	-	-
	➤ Fire service inlet	-	-
	➤ Access to tank	-	-
	• Overhead Tank capacity	-	-
15	Exit Signage.		
		-	-
16	Provision of Lifts.		
	• Pressurization of Lift Shaft	-	-
	• Pressurization of Lift lobby	-	-
	• Communication In lift Car	-	-
	• Fireman's Grounding Switch	-	-
	• Lift Signage	-	-
17	Standby power supply		
		-	-

18	Refuge Area.			
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room			
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

Note:-General requirements for school as per Director of Education Circular dated 17/01/2005

1. Escape route..... **Clear**
2. LPG cylinders in laboratories **No**
3. Electric wiring **Conduit**MCB and ELCB **Provided**
4. Electric meter board **Not Below Staircase**
5. Basement use as per BBL 1983..... **N/A d**
6. Emergency telephone no. board..... **Displayed**.....
7. Generator set..... **No**

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no **F.6/DFS/MS/2011/989** dated **26/05/2011** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Signature]
16/2/15

Signature of the Inspecting Officer

Name

Designation

[Signature]
14.2.15

ADD(BW)

121/PCFO (SM)