

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/CNG/2015/SZ/ 302

DATED: 05/03/15

FIRE SAFETY CERTIFICATE

Certified that the M/s CNG Filling Station (IGL) at Azad Hind Fauj Marg, Sector-14, Dwarka, New Delhi-110075 comprised of ground plus one upper floor was granted NOC by this department vide letter no. F6/DFS/MS/CNG/2012/1693 dated 10.5.2012. The premises was re-inspected by officer concerned of this department on 23.1.2015 in presence of Sh. Kailash Sharma (Addl. Manager) and found that the premises have deemed complied with fire prevention & fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy of CNG Filling Station with effect from ...05.03.15 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, as printed overleaf.

Issued on .....05/03/15..... at New Delhi by



(Dr. GC Misra)  
Chief Fire Officer  
Ph. No.011-23414333

Copy To:-

1. Sh. Alok Sharma, General Manager Fire & Safety IGL Bhawan, Plot No.4, Community Centre, R K Puram, Sector-9, New Delhi.

5/3/15 CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director** in '**Form J**' (**sub Rule (1) of Rule 37**) along with a copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	M/s CNG Filling Station (IGL) at Azad Hind Fauj Marg, Sector-14, Dwarka, New Delhi.		
2	Type of Occupancy	CNG Filling Station		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/CNG/2012/1693 dated 10.5.2012		
5	Fire safety directives letter No	F5/(A3)/ DFS/CNG/BP/2010/292 dated 1.10.2010		
6	Date of inspection	23.1.2015		
7	Name of the inspecting Officers :	ADO S.P Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Sh. Kailash Sharma (Addl. Manager)		
9	Year of construction	2012		
10	Applicant's letter No.	IGL/F&S/2014-15/15/82 dated 9.12.2014	Ground & First Floor	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Requirement</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	9 Mtr	12 Mtrs.	MR
	2) Gate width	5 Mtrs.	5 Mtrs.	old case
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos.	2 Nos.	old case
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	Old Case	120 & 70 cms.	MR
	2. basements	N/A	N/A	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Old Case	1.25 Mtrs.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	N/A	N/A
		12 a/c per hour		
	upper floors		Natural Ventilation	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	20 Nos.	31 Nos.	MR
	Types	Co2 , DCP & ABC	Co2 4.5 Kg. (5Nos.) DCP Trolley of 75 Kgs.(6Nos.)DCP10 Kgs.(20 Nos.)	MR

6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	Total number of hydrants	N/A	N/A	N/A
	Hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level/</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	No smoking Boards	N/A
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


2/2

17	Standby power supply	Required	Provided DG Set	MR
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any:DCP Flooding system for CNG cascade protection and Auto actuated CO2 flooding system for CNG compressor protection.</b>			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/CNG/2012/1693 dated 10.5.2012 under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

**Accordingly DFA is put up for approval and signature please.**



Signature of the Inspecting Officer

Name                      S.P Bhardwaj  
 Designation              ADO (DWARKA)