

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2015 / *school/wz/307*

Dated: *05/03/2015*

FIRE SAFETY CERTIFICATE

Certified that CRPF Public School, Sec-14, Rohini Delhi-110085 comprised of Basement + Ground + Three Upper Floor owned/occupied by CRPF Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2010/1960 dated 02/07/2010. The premises was re-inspected by the officer from this department on dated 18/02/2015 in the presence of Sh. H.R. Sharma (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of NBC Part IV and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 05/03/2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Service Certificate:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the / construction etc. shall be verified by the concerned building sanctioning agency.
5. The basement shall only be used as per BBL 1983.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' (sub rule (1) of rule 37) along with a copy of this Certificate, six months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs. Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in)

Issued onat New Delhi by

Santokh Singh
(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Phone -23414250

Copy to:

1. The Manager, CRPF Public School, Sec-14, Rohini Delhi-110085.
2. The Director of Education, Old Secretariat, Delhi.

OK
OK

N-14

INSPECTION REPORT

B + Gr + 3 floor

1. Name & address of the building : CRPF Public School, Sec-14, Rohini Delhi-110085
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal
 4. Details of previous NOC : Letter No.F-6/DFS/MS/School/2010/3444 Dated: 29/12/2010
 5. Fire Safety directives letter No : NCB Part IV
 6. Date of inspection : 18/02/2015
 7. Name of the Inspecting Officers : ADO (BW)
 8. Name and designation of officers
from the building side : Sh. H.R. Sharma (Principal)
 9. Year of Construction : 1992
 10. Applicant's letter No. : CRPF/(PS)/2014-15 Dated 24/12/2014
- Plot area:-25999.55 m2 Covered area:-8609.84 m2 No.'s of Student:-2126 No.'s of Classrooms:-
53 + 6 labs, 14 rooms for other purpose

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NCB Requirement	Provided at site	Remarks MR/NMR	
1	Access to building				
	• Road width	Accessible	Accessible	MR	
	• Gate width	-Do-	-Do-	MR	
	• Width of internal road	—	—	—	
2	Number, Width, Type & Arrangement of Exits				
	a. Number of staircases				
	• Upper Floors	02	03	MR	
	• Basements	02	02	MR	
	b. Width of staircases	—	—	—	
	• Upper Floors	Old Case	Old Case	Old Case	
	• Basements	Old Case	Old Case	Old Case	
	c. Protection of exits	—	—	—	
	• Fire check door	—	—	—	
	• Pressurization	—	—	—	
	e. No. of continuous staircases to terrace	R	P	MR	
	g. Width of Corridor	—	—	—	
	h. Door Size	Hall CR	1.00 mtr	1.00 mtr	MR

3	Compartmentation.	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust Fan Provided	M/R
	• Upper floors	12 a/c per hour		
5	Fire Extinguishers			
	• Total numbers	34 ABC/Co2 ISI marked	30 5	M/R
	• Types		ABC Co2	M/R
	• IS marking		Yes Yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	3 R 30 m 5 mm	P	M/R
	• Length of hose reel hose		P	M/R
	• Nozzle diameter		P	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	R	P	M/R
9	Public Address System.	R	P	M/R
10	Automatic Sprinkler System.			
	• Basement	R	P	M/R
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	R	P	M/R
	• Number of hydrants per floor	03	03	M/R
	• Hose Box	03	03	M/R

12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	2 X 450 LMP	P	M/R
	➤ Head of the pump	40 m	P	M/R
	➤ Power Supply	R	P	M/R
	➤ Auto Starting of pump	R	P	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	10,0000 ltr	P	M/R
	➤ Draw-off connection	—	P	M/R
	➤ Fire service inlet	—	P	M/R
	➤ Access to tank	—	P	M/R
	• Overhead Tank capacity	15,000 ltr	P	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—

17	Standby power supply	R	P 110 KVA	M/R
18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

Note:-General requirements for school as per Director of Education Circular dated 01/03/2011

1. Escape route.....**Clear**.....
2. LPG cylinders in laboratories**No**.....
3. Electric wiring ...**Concealed**..MCB and ELCB**Provided**.....
4. Electric meter board ...**Not Below**.....**S/C**.....
5. Basement use as per BBL 1983.....**Yes**.....
6. Emergency telephone no. board...**Displayed**.....
7. Generator set.....**Yes 110 KVA**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F-6/DFS/MS/School/2010/3444.dated 29/12/2010 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

