

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/M/S/WR/291

Dated: 02/03/2015


FIRE SAFETY CERTIFICATE

Certified that M/s Ram Kumar Fireworks, 2053, Bawana Road, Narela, Delhi 110040 at ground floor only, measuring 6'.8" x 16', in a three storied building having independent staircase for upper floors, was granted NOC by this department Vide letter no. F5/3A/DFS/10/92 dated 09/04/2010. The premises was re- inspected by the officer concerned of this department on 13/02/2015 in the presence of Sh. Ram Kumar and found that the said fireworks shop have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class Fire Works storage with effect from 02/03/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner canceled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation w.r.t. construction etc shall be verified by concerned building sanctioning authority.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
6. This certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 02/03/2015 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Joint Commissioner of Police (Lic), 1st floor, Police Station Defence Colony, New Delhi w.r.t L.No 1138-39/ Addl. C.P./Lic.(Expl.), dated 14/01/2015
2. The M/s Ram Kumar Fireworks, 2053, Bawana Road, Narela, Delhi 110040

INSPECTION REPORT

1. Name & address of the building : M/S Ram Kumar Fireworks, 2053, Bawana Road, Narela
2. Type of Occupancy : Storage Fire Works
3. Type of Case : Renewal
4. Details of previous NOC : **F5/3A/DFS/10/92 dated 09/04/2010.**
5. Fire Safety directives letter No : Nil
6. Date of : 13/02/2015
7. Name of the Inspecting Officers : DO (N/W)
8. Name and designation of officers
from the building side : Sh. Ram Kumar
9. Year of Construction : 1999
10. Applicant's letter No. : No- 1138-39/ Addl. C. P. / Lic. /Expl./ Dated 14/01/2015

S. No.	Point of inspection	Requirement	Provided at site	Remarks MR/NMR
1	Type of construction and floor area floor level			
	a. Minimum floor area	6', 8" x 16" [old case]	6', 8" x 16"	M/R
	b. Construction	Pucca	Provided	M/R
	c. Premises Location	Not under the staircase / mean of escape	Provided	M/R
	d. Business permissible only at ground floor	Required	Provided	M/R
	e. Business from pavement of road, prohibited.	Required	Provided	M/R
2	Entrance and Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit.	Required	Provided	M/R
3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives / inflammable or hazardous materials	Required	Provided	M/R
4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possessing and sale for	The shop is used for fireworks sale during	Being used for sale of whole sale cold	M/R

5	Type of electrical wiring and electrical fittings			
	a. Preferably concealed or through conduit	Required	Provided	M/R
	b. All electrical fitting should be flame / spark proof	Required	Provided with casing and capping	M/R
6	Extension of shop for business			
	Prohibited	Prohibited	No extension of shop	M/R
7	Approach road			
	The road width on the side of which premises is located should be 12 m	12 m	12 m	M/R
8	Fire protection arrangement			
	a. Extinguishers [Type and No's]	01 no. water type and 01 no. of ABC / Co2 type	Provided	M/R
		02 no's	Provided	M/R
	b. Sand and water buckets	01 no's	Provided	M/R
	c. Water Drum [S]			
9	Any other point that is contrary to the safety of people			

The fire protection systems provided in shop were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter no. **F5/3A/DFS/10/92 dated 09/04/2010**, _renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.



Signature of the Inspecting Officer

Name

Designation

Devo (A/S)

Signature of the Inspecting Officer

Name

Designation

Devo (A/S)
24/2/15
DD (A/S)