

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. *F6/DFS/MS/CNG/2015/S2/405*

Dated: *20/03/15*

FIRE SAFETY CERTIFICATE

Certified that M/S Indraprastha Gas Limited Retail Outlet (CNG Pump) at San Martin, Chankyapuri, New Delhi, comprised of ground floor only, was granted NOC by this department vide letter No. F5/(3A)/DFS/CNG/2006/220, dated 11-05-2006. The premises was re-inspected by the officer concerned of this department on 07-01-2015 in the presence of Sh. Pushendra Sharma (Fire Officer) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class Storage (C.N.G. Pump), 02 Cascades at roof of the office building, 01 Compressor Unit and 05 Dispensing units with effect from ...*20/3/*...2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...*20/3/*... 2015 at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:-

Sh. Alok Sharma, General Manager (Fire & Safety)
IGL Bhawan, Plot No.4, Community Centre,
R.K.Puram, Sector-9, New Delhi-110022.

o/c
h

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S Indraprastha Gas Limited Retail Outlet (CNG Pump)
at San Martin, Chankyapuri, New Delhi.
2. Building is comprised of : Ground floor only.
3. Type of Occupancy : Storage Occupancy (C.N.G. Pump).02 Cascades at roof of the office building, 01 Compressor Unit and 5nos Dispensing units.
4. Type of Case : Renewal
5. Details of Previous NOC : No.F5/(3A)/DFS/CNG/2006/220, Dated 11.05.2006.
6. Fire Safety direction letter No : No.F5/DFS/3A/2000/BP/103, dated 23.03.2000.
7. Date of Inspection : 07.01.15.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Pushpendra Sharma (Fire Officer)
10. Year of Construction : 2000.
11. Applicant's letter No : IGL/F&S/2014-15/15/60, dated 09.12.14

S.No	Minimum Standards on fire prevention and fire safety as per old NOC.	Requirement	Provided at Site	Remarks MR/NMR	
1	Access to building				
	Road width	9 m	12 m	MR	
	Gate width	N.A.	N.A.	N.A.	
2	Width of internal road	N.A.	N.A.	N.A.	
	Number, Width, Type and Arrangement of Exits.				
a. Number of Staircases	Upper Floor	01no.	01no.	MR	
	Basement	N.A.	N.A.	N.A.	
	B. Width of Staircases	Upper Floor	.		
		Basement	70cm	67cm	MR
	c. Protection of exits	Fire check door	N.A.	N.A.	N.A.
		Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace		N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
	g. Width of Corridor		N.A.	N.A.	N.A.
		h. Door Size	1 m	1m	MR
3	Compartmentation				
	Fire check door	N.A.	N.A.	N.A.	
	Sealing of electrical shafts	N.A.	N.A.	N.A.	
	Fire rating of shaft door	N.A.	N.A.	N.A.	
	Water curtain	N.A.	N.A.	N.A.	
4	Fire Dampers	N.A.	N.A.	N.A.	
	Smoke Management System.				
	Basement	30a/c per hour	N.A.	N.A.	
	Upper floor	12 a/c per hour	N.A.	N.A.	



H/6

Indraprastha Gas Limited Retail Outlet (CNG Pump) at San Martin, Chankyapuri, New Delhi.

5.	Fire Extinguisher			
	Total numbers	20 nos.	75kg=03nos,10kg=15nos. 4.5kg=4nos.Total=22nos.	MR
	Types	CO ₂ & ,DCP	CO ₂ & DCP Type	MR
	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system in compressor and in filling area.			
	Type of detectors	Gas & Flame in Compressor & portable gas detector with staff	Gas & Flame in Compressor & portable gas detector with staff	MR
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	Technician room	Technician room	MR
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

Indraprastha Gas Limited Retail Outlet (CNG Pump) at San Martin, Chankyapuri, New Delhi.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
15	Overhead Tank capacity	N.A.	N.A.	N.A.
	No Smoking Signage.(Hindi & English)	Required	Provided in Hindi And English	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
17	Lift Signage	N.A.	N.A.	N.A.
	Standby power supply	N.A.	Provided DG Set 50KVA	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
19	Location	N.A.	N.A.	N.A.
	Fire Control Room			
20	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	Co ₂ flooding system connected through detectors provided in each compressor.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the NOC issued vide letter No: F5/(3A)/DFS/CNG/2006/220, dated 11.05.2006, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

D.O. (South)

29/1/15

Signature of the Inspecting Officer
 Name: Vedpal
 Designation: ADO
 27/1/15