

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/CNG/2015/MO2/315

Dated: 13/03/15

FIRE SAFETY CERTIFICATE

Certified that the CNG station at Vivek Vihar, Delhi, comprised of ground floor only owned/occupied by Indraprastha Gas Limited, have complied with the fire prevention and fire safety requirements as per MOM No.F.2/DFS/HQ/2004/685/D dated 30/04/2004 and verified by the officers concerned of this department on dated 02.01.2015 in the presence of Operator of the CNG station(storage & dispensing unit) and found that the premises is fit for occupancy CNG station with effect from ...13/03/15... for a period of three years, subject to conditions printed overleaf.

Issued on.....13/03/15.....at New Delhi by


11/3
(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333



To,

The General Manager (Fire & Safety)
IGL Bhawan, Plot No. 4, Community Centre,
R.K. Puram Sec-9, New Delhi-22

Conditions

1. No trade susceptible to cause ignition to CNG by generating heat, mechanical/electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipments, electrical gadgets and fitting in the premises shall conform to hazardous area classification for that purpose and be of a type approved by the CCE.
3. In premises "No Smoking" signs board both in Hindi and English shall be displayed in such a manner as to be easily readable by all person.
4. All fire protection arrangements shall be maintained.
5. Nothing contravention of the explosive Act. 1884 and Rules their under 1983, and static and mobile pressure vessels (unfired) Rules 1981 as modified from time to time.
6. All comments/directions of the Chief Inspector of Explosives should always be permitted and followed.

1. Name & address of the building : CNG Dispensing Station at Vivek Vihar, Delhi
2. Building is comprised of : Ground
3. Type of Occupancy : CNG Storage & Dispensing unit
4. Type of Case : New
5. Details of Previous NOC /Site
Clearance : F.5/(3A)/DFS/CNG/2010/224 Dated 22/07/10
6. Fire Safety direction letter No : F.5/DFS/HQ/2004/685/D Dated 30.04.04
7. Date of Inspection : 02.01.2015
8. Name of the Inspecting officers : DO Virendra Singh & ADO Suresh Singh
9. Name and designation of Officer
from the building side : Operator
10. Year of Construction : 2012
11. Applicant's letter No : IGL /F&S/2014-15/15/12 dated 09.12.2014

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtrs.	30 Mtr,	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	• Number of Staircases	N/A	N/A	N/A
	• Width of Staircase	N/A	N/A	N/A
3	Compartmentation	Required	Provided	MR
4	Smoke Management System.	Required	Provided	MR
5.	Fire Extinguisher			
	• DCP Type 10 Kg	15 nos.	26 Nos.	MR
	• DCP Type 75 KG	04 nos.	04 nos.	MR
	• Co2 Type 4.5 Kg	06 nos.	nos.	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	• Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	Gas	Provided	MR
	• Location of main panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters's location	Required	Provided	MR
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A

N/4


13	Pumping Arrangements.			
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage/overhead tank	N/A	N/A	N/A
15	Exit Signage/No smoking Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection			
	• Co2 Local Application	Required	Provided	MR
	• Hand Held Explosive Meter at each Installation	02 Nos.	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as per MOM no. F.5/DFS/HQ/2004/685/D Dated 30.04.04

(i.e as per OISD-179) it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Submitted please.


Signature of the Inspecting Officer
Name: Virendra Singh
Designation: DO(ED)