

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/EH/2015/SZ/ 387

Dated: 19/03/15

FIRE SAFETY CERTIFICATE

Certified that the Godavari Restaurant, Plot No.18, Wadhwa Plaza-III, Central Market, Sector-10, Dwarka, New Delhi-110075, is running at 3rd floor of the building comprised of ground plus three upper floors was granted NOC by this department vide letter no. F6/DFS/MS/EH/2008/2186 Dated 30.7.2008. The premises was re-inspected by officer concerned of this department on 11.3.2015 in the presence of Sh.Kamal Singh (Manager) of the restaurant and found that the premises have deemed complied with fire prevention & fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class D "Assembly building (Restaurant)" with effect from ..19/03/15..... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions as printed overleaf.

Issued on19/03/15..... at New Delhi by



(Dr. GC Misra)
Chief Fire Officer
Ph.011-23414333

OIC



Copy To:-

1. DHO/West Zone, Deputy Health Officer, Municipal Corporation of Delhi, Najafgarh Zone New Delhi.
2. Manager, Godavari Restaurant, 3rd floor, Plot No. 18, Wadhwa Plaza-III, Central Market, Sector-10, Dwarka, New Delhi-110075.

INSPECTION REPORT

1	Name & address of the building	M/S Godavari Restaurant 3rd floor, Plot No. 18, Wadhwa Plaza-III, Sector-10, Dwarka, New Delhi-110075. <i>central market su</i>		
2	Type of Occupancy	Assembly "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/EH/08/2186 dated 30.7.2008.		
5	Fire safety directives letter No	Old Case		
6	Date of inspection	11.3.2015.		
7	Name of the inspecting Officers :	ADO S.P Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Sh. Kamal Singh (Manager)		
9	Year of construction	2005	Restaurant Runinig at 3rd Floor	
10	Applicant's letter No.	DHO/NGZ/2014/2343 Dated 23.12.2014.	Building having Ground + 3 upper Floors	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Old Case /NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	---------------------------	------------------	------------------

1	Access to building			
	1) Road width	Old case	30 mtrs.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases	One	One	MR
	1. Upper floors	One	One	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Old Case	1.20 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Requied	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Old Case	1.22 & 1 Mtrs.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 a/c per hour	Natural Vent.	MR

5	Fire Extinguishers			
	total numbers		8 Nos	MR
	Types		ABC, WCo2,	MR
	ISI marking	ISI	ISI	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	Provided(Smoke)	MR
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	MR
	hooter's location	N/A	N/A	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450, 180 LPM	450 ,180 LPM	MR
	b. head of the pump	Old Case	30 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings vide letter no. F6/DFS/MS/2015/SZ/restaurant/122 dated 15.1.2015 found rectified.

Keeping in view the demmed compliance of the minimum standards on fire prevention and fire safety required under the rules, the renewal of Fire Safety Certificate issued vide letter no. DFS/MS/EH/08/2186 dated 30.7.2008 is recommended under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.


Signature of the Inspecting Officer

Name S.P Bhardwaj

Designation ADO (DWARKA)

Doket