

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2015/NO2/376

Dated: 17/03/15

FIRE SAFETY CERTIFICATE

Certified that the Govt.Girls Sec. School No.2 at Gandhi Nagar,Delhi-31, owned/occupied by, Govt.Girls Sec. School comprised of ground plus one upper floor was issued Fire Safety Certificate vide letter no. No.F.6/DFS/MS/School/2012/1400 dated 19/04/12.The school building was inspected by the officer concerned of this department on 24.02.15 in the presence of Mrs.Popinder Kaur (Principal) of school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the GF+FF of building is fit for occupancy class B "Educational Building" with effect from ..17/03/15..... for a period of three years, subject to conditions printed overleaf.

Issued on ..17/03/15..... at New Delhi by


(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333



To,

The Principal
Govt.Girls Sec. School No.2,
Gandhi Nagar,Delhi-31.

Copy to:-

- 1.The joint Director of Education
Land & Estate)
Directorate of Education
Lucknow Road,Delhi -54.
2. The Principal
Govt.Boys Sr. Sec. School No.2,
Gandhi Nagar,Delhi-31.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6 "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

plc

1. Name & address of the building : Govt. Girls Senior Secondary School No.2, Gandhi Nagar Delhi-31
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/School/2012/1400 dated 19.04.12
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
7. Date of Inspection : 24.02.15
8. Name of the Inspecting Officers: : Virendra Singh (DO)
9. Name of the designation of Officer from the building side : Mrs. Popinder Kaur , Principal
10. Year of Construction : 2009-2011
11. Applicant's letter No : 8233 Dated 28.01.15

| S.No | Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11 | Requirement | Provided at Site | Remarks MR/NMR |
|------|--|-------------|------------------|----------------|
| 1 | Access to building | | | |
| | Road width | 6 m | 6 m | MR |
| | Gate width | N.A | 3.9 M | MR |
| | Width of internal road | N.A. | N.A. | N.A. |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | Upper Floor | 03 no. | 03 no. | MR |
| | Basement | N.A | N.A. | N.A. |
| | B. Width of Staircases | | | |
| | Upper Floor | 1.5 m | 1.5 & 1.44 M | MR |
| | Basement | N.A | N.A. | N.A. |
| | c. Protection of exits | | | |
| | Fire check door | N.A | N.A. | N.A. |
| | Pressurization | N.A. | N.A. | N.A. |
| | d. No. of continuous staircases to terrace | N.A. | N.A. | N.A. |
| | e. Width of Corridor | 1.5 m | 1.5 m | MR |
| | f. Door Size | 1 m | 1 m | MR |
| 3 | Compartmentation Provided | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Sealing of electrical shafts | N.A. | N.A. | N.A. |
| | Fire rating of shaft door | N.A. | N.A. | N.A. |
| | Water curtain. | N.A. | N.A. | N.A. |
| | Fire Dampers | N.A. | N.A. | N.A. |
| 4 | Smoke Management System. | | | |
| | Basement | N.A. | N.A. | N.A. |
| | Upper floor | N.A. | N.A. | N.A. |


| | | | | |
|----|---|-----------------------|-----------------------|------|
| 5. | Fire Extinguisher | | | |
| | Total numbers | 08 no. | 10 no. | MR |
| | types | CO ₂ & ABC | CO ₂ & ABC | MR |
| | IS marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N.A. | N.A. | N.A. |
| | Length of hose reel hose | N.A. | N.A. | N.A. |
| | Nozzle diameter | N.A. | N.A. | N.A. |
| 7 | Automatic fire detection and alarming system. | | | |
| | Type of detectors | N.A. | N.A. | N.A. |
| | Location of main panel | N.A. | N.A. | N.A. |
| | Location of repeater panel | N.A. | N.A. | N.A. |
| | Alternate source of power | N.A. | N.A. | N.A. |
| | Hooters's location | N.A. | N.A. | N.A. |
| 8 | MOEFA | N.A. | N.A. | N.A. |
| 9 | Public address System. | N.A. | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | Basement | N.A. | N.A. | N.A. |
| | upper floor | N.A. | N.A. | N.A. |
| | sprinkler above false ceiling | N.A. | N.A. | N.A. |
| 11 | Internal Hydrants | | | |
| | size of riser/down-comer | N.A. | N.A. | N.A. |
| | Number of hydrants per floor | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 12 | Yard Hydrants. | | | |
| | Total number of hydrants | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of main Pump | N.A. | N.A. | N.A. |
| | ➤ Head of Main Pump | N.A. | N.A. | N.A. |
| | ➤ Number of main pumps | N.A. | N.A. | N.A. |
| | ➤ Jockey pump out put | N.A. | N.A. | N.A. |
| | ➤ Jockey pump head | N.A. | N.A. | N.A. |
| | ➤ Standby pump out put | N.A. | N.A. | N.A. |
| | ➤ Standby pump Head | N.A. | N.A. | N.A. |
| | ➤ Auto Starting /Manual stopping | N.A. | N.A. | N.A. |
| | ➤ Pump House Access | N.A. | N.A. | N.A. |
| | • Terrace Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of pump | N.A. | N.A. | N.A. |
| | ➤ Head of the Pump | N.A. | N.A. | N.A. |
| | ➤ Power supply | N.A. | N.A. | N.A. |
| | ➤ Auto Starting of pump | N.A. | N.A. | N.A. |

N/8

| | | | | |
|----|--|------|------|------|
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | Underground tank capacity | N.A. | N.A. | N.A. |
| | Draw-off connection | N.A. | N.A. | N.A. |
| | Fire service inlet | N.A. | N.A. | N.A. |
| | Access to tank | N.A. | N.A. | N.A. |
| | Overhead Tank capacity | N.A. | N.A. | N.A. |
| 15 | Exit Signage. | | | |
| 16 | Provision of Lifts. | | | |
| | Pressurization of Lift Shaft | N.A. | N.A. | N.A. |
| | Pressurization of Lift lobby | N.A. | N.A. | N.A. |
| | Communication in lift car | N.A. | N.A. | N.A. |
| | Firemen's grounding switch | N.A. | N.A. | N.A. |
| | Lift Signage | N.A. | N.A. | N.A. |
| 17 | Standby power supply | | | |
| 18 | Refuge Area. | | | |
| | Total area | N.A. | N.A. | N.A. |
| | Location | N.A. | N.A. | N.A. |
| 19 | Fire Control Room | | | |
| | Detector system panel | N.A. | N.A. | N.A. |
| | Flow switch panel | N.A. | N.A. | N.A. |
| | PA system panel | N.A. | N.A. | N.A. |
| | Batter backup | N.A. | N.A. | N.A. |
| | Building Floor Plans | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | | | |
| | | N.A. | N.A. | N.A. |

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F.6/DFS/MS/School/2012/1400 dated 19.04.2012 renewal under the circular No. 3298 to 3398 dated 01.03.11 is recommended.

Submitted please.


 Signature of the Inspecting Officer
 Name:-Virendra Singh
 Designation:-DO (ED)