

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/School/2015/ND2/314

Dated: 09/03/15

FIRE SAFETY CERTIFICATE

Certified that the M.K.S. Memorial Public School running on ground floor of the building comprising of ground plus first floor only at A-6, Jagatpuri Extn., 100 Futta Road, Near Railway Crossing, Shahdara, Delhi -110093, owned/occupied by M.K.S. Memorial Public School was granted NOC vide letter no-F.6/DFS/MS//2008/1443 dated-30/05/2008. The school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No.262-362 Dated-17/01/05 issued by Director of Education and verified by the officer concerned of this department on 24/02/2015 in the presence of Mr. Rajpal Singh, Manager of the school and found that the school building is fit for occupancy class "B" 'Educational Building' for ground floor with effect from ... 09/03/15 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 09/03/15 at New Delhi by



(Dr. G. C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph.011-23414333

To,  
The Principal,  
M.K.S. Memorial Public School,  
A-6, Jagatpuri Extn., 100 Futta Road,  
Near Railway Crossing, Shahdara, Delhi -110093

Copy:-  
The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi-110053

O/c  
H

1. Name & address of the building : M.K.S. Memorial Public School,  
A-6, Jagatpuri Extn., 100 Futta Road,  
Near Railway Crossing, Shahdara, Delhi-110093
2. Building is comprised of : Ground plus first floor  
(School is running on ground floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/2008/1443 Dated-30/05/2008
6. Fire Safety direction letter No : Dir. of Edu. Circular Letter No.262-362 Dated-17/01/05
7. Date of Inspection : 24/02/2015
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer  
from the building side : Mr. Rajpal Singh (Manager)
10. Year of Construction : 2002
11. Applicant's letter No : Letter No.-Nil, Dated- 16/02/2015

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	12 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01	01	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	N/A	0.96M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A




05.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>types</li> <li>IS marking</li> </ul>	02 nos.	04 nos.	MR
		ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
		ISI marked	ISI marked	MR
06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of main panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of repeater panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>upper floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose box</li> </ul>	N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose box</li> </ul>	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of Main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby pump Head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting /Manual stopping</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of the Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection. The school building was issued NOC earlier vide letter no. - F.6/DFS/MS/2008/1443 dated-30/05/2008

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular- Director of Education Letter No.262-362 Dated-17/01/05, it is recommended to renew Fire Safety Certificate.

  
 Signature of the Inspecting Officer  
 Name- Vijay Bahadur  
 Designation- A.D.O

Do(ED)

Submitted for approval please.