

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/Indl/2015/ 82/373

Dated: 17/03/15

FIRE SAFETY CERTIFICATE

Certified that the **M/s Lord's Homoeopathic Laboratory Pvt. Ltd.** located at C-106/5, Naraina Industrial Area, Phase-I, New Delhi-110028 is comprised of Basement, Ground Floor, mezzanine floor & first floor was issued NOC by this department vide letter No.F.5/(5)/DFS/2010/109 dated 27.04.2010 owned/ occupied by the management of Lord's Homoeopathic Laboratory Pvt. Ltd. The Industrial building was re- inspected by the officers concerned of this department on 05.03.2015 in the presence of Sh. Rajesh Sharma and found that the management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Group G industrial building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....17/03/15.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph: 011-23414333

Copy to:-

1. Sh. S.M. Sharma (Mg. Director)
M/s Lord's Homoeopathic Laboratory Pvt. Ltd,
C-106/5, Naraina Industrial Area, Phase-I, N.D-28.
2. The District Excise Officer (M & TP)
Office of the Commissioner of Excise,
L & N Block, Vikas Bhawan, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Lord's Homoeopathic Laboratory Pvt. Ltd, C-106/5
2. Type of Occupancy : Group G (Industrial Bldg.) Naraina Ind. Area, Ph-I,
New Delhi - 110028.
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. FS/LS/DFS/10/109 Date 27.04.2010
5. Fire Safety directives letter No. : -
6. Date of inspection : 05.03.2015
7. Name of Inspecting Officer : D.O.S.K. Tomar & A.D.O P.S. Sahija
8. Name and designation of officers
From the building side : Sh. Rajesh Sharma
9. Year of Construction : 1999-2000
10. Applicant's letter No. : NIL dated 06.02.2015

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC/BBL Requirement | Provided at site | Remarks MR/NMR |
|--------|---|------------------------|----------------------------------|---------------------|
| 1. | Access to building | | | |
| | • Road width | <u>Accessible</u> | <u>12 mtr</u> | <u>MR</u> |
| | • Gate width | <u>-</u> | <u>270 cms</u> | <u>MR</u> |
| | • Width of internal road | <u>-</u> | <u>-</u> | <u>-</u> |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | <u>Two</u> | <u>Two</u> | <u>MR</u> |
| | • Basements | <u>- do -</u> | <u>- do -</u> | <u>MR</u> |
| | b. Width of staircases | | | |
| | • Upper Floor | <u>-</u> | <u>120cms, 112cms</u> | <u>MR, Old Case</u> |
| | • Basements | <u>-</u> | <u>155cms, 85cms</u> | <u>- do -</u> |
| | c. Protection of exits | | | |
| | • Fire check door | <u>-</u> | <u>-</u> | <u>-</u> |
| | • pressurization | <u>-</u> | <u>-</u> | <u>-</u> |
| | d. No. of continuous staircases to terrace | <u>-</u> | <u>One</u> | <u>-</u> |
| | e. Width of Corridor | <u>-</u> | <u>180cms, 210cms</u> | <u>-</u> |
| | f. Door Size | <u>-</u> | <u>140cms x 204cms</u> | <u>-</u> |
| 3. | Compartmentation | | | |
| | • Fire check door | <u>-</u> | <u>-</u> | <u>-</u> |
| | • Sealing of electrical shafts | <u>-</u> | <u>Sealed</u> | <u>-</u> |
| | • Fire Rating of shaft door | <u>-</u> | <u>-</u> | <u>-</u> |
| | • Water Curtain | <u>-</u> | <u>-</u> | <u>-</u> |
| | • Fire Dampers | <u>-</u> | <u>-</u> | <u>-</u> |
| 4. | Smoke Management System | | | |
| | • Basements | <u>30 a/c per hour</u> | <u>Exhaust fans are Provided</u> | <u>MR</u> |
| | • Upper floors | <u>- do -</u> | <u>- do -</u> | <u>MR</u> |

M/19.

C-106/S, Naraina Industrial Area,
Phase-I, New Delhi - 110028.

| | | | | |
|------------|---|--|---|--|
| | <ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | <p>—</p> <p>—</p> <p>—</p> <p>Required</p> <p>—</p> | <p>—</p> <p>—</p> <p>456 LPM, 180 LPM</p> <p>30M Each Provided</p> <p>—</p> | <p>—</p> <p>—</p> <p>MR, Old Case</p> <p>MR</p> <p>MR</p> <p>—</p> |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>10000 Ltr</p> <p>Required</p> | <p>—</p> <p>—</p> <p>Provided</p> <p>—</p> <p>10000 Ltr</p> <p>Provided</p> | <p>—</p> <p>—</p> <p>MR</p> <p>—</p> <p>MR</p> <p>MR</p> |
| 15. | Exit Signage. | | | |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>Required</p> | <p>—</p> <p>—</p> <p>Provided</p> <p>—</p> <p>—</p> <p>Provided</p> | <p>—</p> <p>—</p> <p>MR</p> <p>Old Lift</p> <p>—</p> <p>MR</p> |
| 17. | Standby power supply | | | |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | <p>—</p> <p>—</p> | <p>—</p> <p>—</p> | <p>—</p> <p>—</p> |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans | <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> | <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> | <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | | | |

41

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F5/LS/DFS/10/109 dated 27.04.2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


S.K. Tomar
21/3/15

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer


P.S. Sahiya
19/3/15

Signature of Inspecting Officer

Name P.S. Sahiya

Designation Asstt. Divisional Officer