

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2015/WZ/362

Dated: 16/03/2015

FIRE SAFETY CERTIFICATE

Certified that M/S VNV BEAUTY PRODUCTS, Plot No- L - 85, Sec-2, DSIIDC Bawana Industrial Area, Delhi-110039 located at Ground floor of a premise comprised of Basement + Ground + Two Upper Floors owned/occupied by M/S VNV BEAUTY PRODUCTS, have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010, and verified by the officer concerned of Fire Service on 14/02/2015 in the presence of Sh. Sanjay Batra and that the ground floor of building /premises is fit for occupancy Industrial G-2 (ii) building with effect from 16/03/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. **The basement and upper floors shall not be used for manufacturing of Nail Polish.**
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on...16/03/15.....at New Delhi.


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:-

1. M/S VNV BEAUTY PRODUCTS, Plot No- L - 85, Sec-2, DSIIDC Bawana Industrial Area, Delhi-110039
2. The Assistant Drugs Controller & Licensing Authority, Govt. of NCT of Delhi, F-17, Karkardooma, New Delhi-110032

INSPECTION REPORT**Premise-Basement, Ground + Two Upper Floor****Use- [i] Basement and first Floor lying vacant.****[ii] Ground floor- For use as manufacturing nail polish****[iii] 2nd floor- 02 rooms used as servant quarters**

1. Name & address of the building : M/s VNV BEAUTY PRODUCTS, Plot No- L-85, Sec-2, DSIDC Bawana Industrial Area, Delhi
2. Type of Occupancy : Industrial G-2[ii] **(FSC for Ground floor only)**
3. Type of Case : New Case
4. Details of previous NOC : Letter No. Nil Dated: Nil
5. Fire Safety directives letter No : NBC
6. Date of inspection : 14/02/2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers from the building side : Sh. Sanjay Batra
9. Year of Construction : 2014
10. Applicant's letter No. : L. No F.NW-03/Cos/15/39 dated 09/01/2015

Plot Area- 100 yds.

S/No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M.R.
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			(FSC for Ground floor only)
	a. Number of staircases			
	• Upper Floors	N.A	1	N.A
	• Basements	N.A	1	N.A
	b. Width of staircases			
	• Upper Floors	—	112 to 124	—
	• Basements	—	109 cm	—
	c. Protection of exits	—	—	—
	Fire check door	—	—	—
	Pressurization	—	—	—
	e. No. of continuous staircases to terrace	N.A	1	N.A

	g. Width of Corridor	—	—	—
	h. Door Size	1 mtr x 2	137 cm and 105 cm + One Shutter 2 mtr	M/R
3	Compartmentation.			
	• Fire check door	N.A	N.A	N.A
	• Sealing of electrical shafts	N.A	N.A	N.A
	• Fire Rating of shaft door	N.A	N.A	N.A
	• Water Curtain	N.A	N.A	N.A
	• Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	• Basements	R	Exhaust fan provided	M.R
	• Upper floors	30 a/c per hour 12 a/c per hour	Exhaust fan provided	M.R
5	Fire Extinguishers			
	• Total numbers	05 no's	P	M.R.
	• Types	ABC	P	M.R.
	• IS marking	ISI marked	P	M.R.
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One	Provided on each floor	M.R.
	• Length of hose reel hose	30mm	P	M.R.
	• Nozzle diameter	5mm	P	M.R.
7	Automatic fire detection and alarming system.			
	• Type of detectors	N.A	N.A	N.A
	• Location of Main Panel	N.A	N.A	N.A
	• Location of Repeater Panel	N.A	N.A	N.A
	• Alternate source of power	N.A	N.A	N.A
	• Hooters' Location	N.A	N.A	N.A
8	MOEFA	N.A	N.A	N.A
9	Public Address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	• Basement	—	P	—
	• Upper Floor	R	P	M.R
	• Sprinkler above false ceiling	—	—	—

11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N.A	N.A	N.A
		N.A	N.A	N.A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		900 LPM	P	MR
		40 m	P	MR
		R	P	MR
		R	P	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		15,000 ltrs.	P	MR
		R	P	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N.A	N.A	N.A
		N.A	N.A	N.A

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	Fire Control Room			
	• Detector System Panel	N.A	N.A	N.A
	• Flow Switch Panel	N.A	N.A	N.A
	• PA System Panel	N.A	N.A	N.A
	• Batter backup	N.A	N.A	N.A
	• Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	Nil	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

DO (NW)

Designation

[Signature]
3/3/15
DO (NW)

as per contact

16/12/2015