

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110**

Fax:- 011-23412593

E-mail ID: cfhq.dlfire@nic.in


No.F6/DFS/MS/2015/ School/ *MD2/379*

Dated: *17/03/15*

**FIRE SAFETY CERTIFICATE**

Certified that the **N. P. Primary School** located at **Pandara Road, New Delhi** comprises of **Ground + One floor** was granted NOC to this department vide letter No. **F6/DFS/MS/School/2011/2636 dated 21/10/2011**. The premises was re-inspected by the officer concerned of this department on 16-02-2015 in the presence of Mr. Anil Kumar Saha (Fire Officer) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building"** as above with effect from ~~---~~*17/03/*2015 for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on *17/03/15* at New Delhi by.



(**Dr.G.C.Misra**)  
Chief Fire Officer  
Ph -011-23414333

Copy to:-

1. The Principal, N. P. Primary School , Pandara Road, New Delhi
2. Director of Education, Govt. of NCT, Delhi.
3. Anil Kumar Saha, Fire officer, NDMC, Palika Kender, New Delhi.

*ok*  
*me*

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

N/B

**INSPECTION REPORT**

1. Name & address of the building : **N. P. Primary School** located at **Pandara Road, New Delhi**
2. Type of Occupancy : Educational Building (Ground + One floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS2011/School/2636 dated 21/10/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 16/02/2015
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer  
from the building side : Mr. Anil Kumar Saha (Fire Officer)
- 9 Year of Construction : 1961
10. Applicant's letter No. : Letter No. NIL Dated 22/09/2014.

S No	Minimum standards on fire prevention and fire safety	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Approachable	06 Mtr.	MR
	• Gate width	Approachable	05 Mtr.	MR
	• Width of internal road	NA	05 Mtr.	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25 Mtr.	1.10 & 1.20 Mtr.	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

ML

	d. No of continuous staircase to terrace	NA	01	MR
	e. Width Of Corridor	NA	1.5 Mtr	MR
	f. Door Size	1.0 mt.	1.30 mt.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	04 Nos.	12 Nos.	MR
	• Types	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	NA	Provided 1 Nos.	MR
	• Length of hose reel hose	NA	30 Mtr.	MR
	• Nozzle diameter	NA	5 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	Provided	MR
10	Automatic Sprinkler			
	• Basements	NA	NA	NA



	Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	NA	450LPM	MR
	• Head of the pump	NA	40 Mtr.	MR
	• Power supply	NA	Provided	MR
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	5000 ltr.	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA

N/A

	• Overhead Tank capacity	2500 ltr.	2500 ltr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co <sub>2</sub>	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS2011/2636 dated 21/10/2011 renewal under the Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011.

Signature of the Inspecting Officer

*M.K. Sharma*

Name :- M.K. Sharma  
Designation :- A. D.O. (CC)



*DO (CC)*

*13/3/15*