

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2015/ *school/wz/1341*

Dated: *13/03/2015*

FIRE SAFETY CERTIFICATE

Certified that Nav Jyoti Public School, C-6, Shardha Nand Colony, Delhi- 110042 has already been issued fire safety certificate for Ground + One Upper Floor of a Building vide letter no. F-6/DFS/MS/2011/1892 dated 05/08/2011. The premises was re-inspected by the officer from this department on dated 23/12/2014 in the presence of Smt. Vimlesh Sharma (Manager) and observed that two rooms on 2nd floor have been added for residence of security guard. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education letter Circular No 262-362 dated 17/01/2005 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 13/03/2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/03/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:-

1. The Principal, Nav Jyoti Public School, C-6, Shardha Nand Colony, Delhi- 110042
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

Building Ground + Two Upper Floor
2nd Floor used for residence of S. Guard
FSC for Ground + One Upper Floor

1. Name & address of the building : Nav Jyoti Public School, C 6, Shardha Nand Colony Delhi
2. Type of Occupancy : **Educational**
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2011/1892 dated 05/08/2011
5. Fire Safety directives letter No : Director of Education dated 17/01/2005
6. Date of inspection : 22/01/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Smt. Bimlesh Sharma, Manager
9. Year of Construction : 1998
10. Applicant's letter No. : NJPS/Fire Safety/2014 dated 10/12/2014

Plot Area- 200 Sq.mtr. Covered Area-450 Sq.mtr. No of Student- 285 Class Room-12

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	Accessible	Accessible	M/R
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	M/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.50 mtr	1.12 and 0.82 mtr	M/R
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	--	--	--
	f. Door Size	Old case	Old case	Old case

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	07	07	M/R
			ABC	M/R
		ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One	P	M/R
		30 m	P	M/R
		5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12	Yard Hydrants.			

	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		220 LPM	P	M/R
		40 m	P	M/R
		--	--	--
		--	--	--
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		2500 ltr	P	M/R
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area 	N/A	N/A	N/A

	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note: - General requirements for schools as per Director of Education circular dated ...17/01/2005

1. Escape route **Clear**.....
2. LPG cylinders in laboratories **Not in use**.....
3. Electric wiring **Concealed**.....
4. MCB and ELCB at Electric circuit ... **Provided**.....
5. Electric meter board **Not below stair case**.....
6. Basement use as per BBL 1983 **N/A**.....
7. Emergency telephone no. board **Displayed**.....
8. Generator set **Nil**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2011/1892 dated 05/08/2011**. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Signature]
[Signature]
 3/3/15

Signature of the Inspecting Officer

Name

Designation

[Signature]
 2-3-15
 H.S.D. (W)

necessary correction made in performance pt.

DFS (WP)

CFD *keentel*
 4/3

see please

118/DFS @ 20
5/3/15/11/3

CFD/1392
9/8/15