

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

Fax:- 011-23412593

E-mail ID: cfhq.dlfire@nic.in

No.F6/DFS/MS/2015/ School/ *ND2/380*

Dated: *17/03/15*

FIRE SAFETY CERTIFICATE

Certified that the **Navyug Primary School** located at **Pataudi House, New Delhi** comprises of **Ground + One floor (below 09 meters in height)** was granted NOC to this department vide letter No. **F6/DFS/MS/School/2011/2730 dated 28/11/2011**. The premises was re-inspected by the officer concerned of this department on 05-02-2015 in the presence of Mr. Anil Kumar Saha (Fire Officer) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building"** with effect from ----- *17/03/*2015 for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on *17/03/15* at New Delhi by.



(Dr.G.C.Misra)
Chief Fire Officer
Ph -011-23414333

Copy to:-

1. The Principal, Navyug Primary School, Pataudi House, New Delhi
2. Director of Education, Govt. of NCT, Delhi.
3. Anil Kumar Saha, Fire officer, NDMC, Palika Kender, New Delhi.



Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : **Navyug Primary School** located at **Pataudi House, New Delhi**
2. Type of Occupancy : Educational Building (Ground + One floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS2011/School/2730 dated 28/11/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 05/02/2015
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Mr. Anil Kumar Saha (Fire Officer)
- 9 Year of Construction : 1993-94
10. Applicant's letter No. : Letter No. NIL Dated 22/09/2014.

S No	Minimum standards on fire prevention and fire safety	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> More then 06 Mtr. Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 01 NA 	<ul style="list-style-type: none"> 02 NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1.25 Mtr. NA 	<ul style="list-style-type: none"> Iron S/C 1.27 Mtr. R.C.C S/C 1.25 to 1.30 Mtr. NA 	<ul style="list-style-type: none"> NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> NA

	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.0 mt.	1.25 mt.	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	04 Nos.	12 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First - Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	NA	Provided 2 Nos.	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	NA	30 Mtr.	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	NA	5 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System			
		NA	Provided	MR
10	Automatic Sprinkler			

	<ul style="list-style-type: none"> • Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	NA	2500 ltr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS2011/School/2730 dated 28/11/2011 renewal under the Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011.

Signature of the Inspecting Officer

Name :- M.K. Sharma

Designation :- A. D.O. (CC)

