

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2015/356

Dated: 13/03/2015

FIRE SAFETY CERTIFICATE

Certified that Nigam Pratibha Bal Vidyalaya, Sangam Park, Delhi-110007 comprised of Ground Floor Only owned/occupied by Nigam Pratibha Bal Vidyalaya was issued Fire Safety Certificate Vide letter no F-6/DFS/MS/2008/1173 dated 23/04/2008. The premises was re-inspected by the officer concerned of this department on 30/01/2015 in the presence of Sh Naveen Dabas (Teacher-in-charge) and observed that the premises have complied with fire prevention & fire safety requirement in accordance with the circular no. 262-362 dated 17/01/05 issued by Director of Education. The premise is fit for occupancy of Group Class B (Educational) with effect from 13/03/2015 for a period of three years, subject to conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/03/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250



Copy to:

1. The Principal, Nigam Pratibha Bal Vidyalaya, Sangam Park, Delhi-110007
2. The Addl. Director of Education, NDMC, Civic Centre, New Delhi.

9th floor only

INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Bal Vidhyalaya Sangam Park, Delhi-07
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. _____ Nil _____ Dated: 27/11/2014
5. Fire Safety directives letter No : Dir of Edu. Cir. 17/01/2005
6. Date of inspection : 30/01/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Sh Naveen Dabas (Teacher- in-charge)
9. Year of Construction : 1989 & 1995
10. Applicant's letter No. : Nil Dated 27/11/2014

Plot area:-9000 sq,mtr Covered area:- 1074 sq,mtr No. of students:-196 No's of classrooms:-13
9Room for other purpose

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir of Edu Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	Accessible	Accessible	M/R
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1.00 mtr	1.00 mtr	M/R

3	Compartmentation.					
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-	-	-	-	-
4	Smoke Management System.					
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	-	-	-	-
		12 a/c per hour	-	-	-	-
5	Fire Extinguishers					
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	5ABC ISI marked	7	M/R		
			ABC	M/R		
			Yes	M/R		
6	First-Aid Hose Reels.					
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	-	-	-	-
7	Automatic fire detection and alarming system.					
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	-	-	-	-	-
8	MOEFA			-	-	-
9	Public Address System.			-	-	-
10	Automatic Sprinkler System.					
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	-	-	-	-	-
11	Internal Hydrants					
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	-	-	-	-	-
		-	-	-	-	-
		-	-	-	-	-

12	Yard Hydrants.		
	• Total number of hydrants	-	-
	• Hose Box	-	-
13	Pumping Arrangements.		
	• Ground Level	-	-
	➤ Discharge of main Pump	-	-
	➤ Head of Main pump	-	-
	➤ Number of main pumps	-	-
	➤ Jockey Pump out put	-	-
	➤ Jockey pump head	-	-
	➤ Standby Pump out put	-	-
	➤ Standby Pump Head	-	-
	➤ Auto Starting/ Manual stopping	-	-
	➤ Pump House Access	-	-
	• Terrace level	-	-
	➤ Discharge of pump	-	-
	➤ Head of the pump	-	-
	➤ Power Supply	-	-
	➤ Auto Starting of pump	-	-
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	-	-
	➤ Draw-off connection	-	-
	➤ Fire service inlet	-	-
	➤ Access to tank	-	-
	• Overhead Tank capacity	-	-
15	Exit Signage.		
		-	-
16	Provision of Lifts.		
	• Pressurization of Lift Shaft	-	-
	• Pressurization of Lift lobby	-	-
	• Communication In lift Car	-	-
	• Fireman's Grounding Switch	-	-
	• Lift Signage	-	-
17	Standby power supply		
		-	-

18	Refuge Area.			
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room			
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

Note:-General requirements for school as per Director of Education Circular dated 17/01/2005.

1. Escape route.....**Clear**.....
2. LPG cylinders in laboratories**No**.....
3. Electric wiring**Conduit**.....MCB and ELCB**Provided**.....
4. Electric meter board**Not Below Staircase**.....
5. Basement use as per BBL 1983...**N/A**.....
6. Emergency telephone no. board...**Displayed**.....
7. Generator set.....**No**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NCC issued vide letter no.F.6/DFS/MS/2008/1173.dated 23/04/2008 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
[Handwritten Signature]

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
14.2.15
[Handwritten Designation]

