

Form H
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI

No. F6/DFS/MS/EH/2015/102/394

Dated: 20/03/15

FIRE SAFETY CERTIFICATE

Certified that the O2 Multicuisine Restaurant located at Ground and First Floor , A-23, NN Tower, B-Block Road No. 44, DDA Commercial Complex, Pitam Pura and Gola Sizzlers Restaurant at First Floor, A-23,Block –A NN Tower DDA Complex, Pitam Pura were issued FSC by this department vide letter no. F6/DFS/MS/EH.2013/194 dated 23/04/2013 and F6/DFS/MS/2014/EH/WZ/1024 dated 12/08/14 respectively. The Gola Sizzlers Restaurant on FF is merged with O2 Multicuisine Restaurant. The premises was re-inspected by the officers concerned of this department on 16/02/2015 in the presence of Mr. M. S. Rana (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 20/3/15 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/3/15 at New Delhi by.

Copy to:

1. Mr. M.S. Rana
A-23, Block A & B, NN Towers
Community Center, Road No. 44
Pitam Pura, Delhi- 110034.


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Ph:011-2341250

Following fire safety directives must be adhered to:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be a the risk and responsibility of the management.
3. The tained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of the unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner /occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

May kindly peruse letter no. DHO/RZ/2015/1559 dated 09.02.15 received from DHO Rohini Zone, NDMC in r/o O2 Multicuisine Restaurant, where in increase of seats upto 192 requested and this premises has already been issued NOC vide F6/DFS/MS/EH/2013/194 dated 23/04/13. The fire safety arrangements are as below:

Inspection Report

1. Name & address of the building : O2 Multicuisine Restaurant at A-23, Block A & Block B, NN Towers, Community Centre, Road No. 44, Pitampura, Delhi-110034
 2. Type of Occupancy : Assembly (G+1 Upper Floor)
 3. Type of Case : ~~Renewal~~ *New* (Addition of seats from 150 to 192) *dn*
 4. Details of previous NOC : F6/DFS/MS/EH/2013/194 dated 23/04/13
 5. Fire Safety directives letter No. : Nil
 6. Date of inspection : 16/02/2015
 7. Name of the Inspecting Officers : D.O. (West)
 8. Name and designation of officers : Mr. M.S. Rana (Manager)
- From the building side
9. Year of Construction : 2005
 10. Applicant's letter No. : DHO/RZ/2015/1559 dated 09.02.15

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	NA	NA	NA
	• width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	3 Provided	MR

<ul style="list-style-type: none"> • Basement b. Width of staircases <ul style="list-style-type: none"> • Upper Floors • Basement c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No. of continuous staircases to terrace e. Width of Corridor f. Door size	NA	NA	NA
	200 cm	1x100cm, 1x142cm, 1x215 cm	MR
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	200 cm & 1x1.25cm	1x 200 cm, 1x125 cm, 1x120 cm & 1x 100 cm	MR
	3.	Compartmentation.	
<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts. • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required in kitchen	Provided in	M.R.
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
4.	Smoke Management System.		
<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
	12 a/c per hour	Provided	M.R.
5.	Fire Extinguishers		
<ul style="list-style-type: none"> • Total numbers • Types 	12 no	Provided	M.R.
	ABC type & CO ² type ISI marked	Provided	M.R.


	<ul style="list-style-type: none"> IS marking 		Provided	M.R.
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	02	Provided	M.R.
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 mtrs length	M.R.
	<ul style="list-style-type: none"> Nozzle diameter 	6.5 mm	Provided	M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooter's Location 	NA	NA	NA
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	NA	Provided	M.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	M.R.
	<ul style="list-style-type: none"> Number of hydrants per floor 	2	Provided	M.R.

	Required	Provided	MR
• Hose Box			
12. Yard Hydrants.			
	NA	NA	NA
• Total number of hydrants		NA	NA
• Hose Box			
13. Pumping Arrangements.			
Ground Level			
➤ Discharge of main pump	NA	NA	NA
➤ Head of Main pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey Pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby pump out put	NA	NA	NA
➤ Standby pump Head	NA	NA	NA
➤ Auto Starting/Manual stopping	NA	NA	NA
➤ Pump House Access	NA	NA	NA
Terrace level			
➤ Discharge of pump	2 x 450 lpm 180 lpm	Provided	M.R.
➤ Head of the pump	36 mtr	Provided	M.R.
➤ Power supply	Required	Provided	M.R.
➤ Auto Starting of pump	Required	Provided	M.R.

14.	Captive Water Storage for fire fighting.		
	Underground tank capacity	NA	NA
	➤ Draw -off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA
	➤ Overhead Tank Capacity	2 x 5000 lts	NA MR
15	Exit Signage.	Required	Provided M.R.
16.	Provision of Lifts		
	• Pressurization of Lift Shaft	NA	NA
	• Pressurization of Lift lobby	NA	NA
	• Communication In lift Car	NA	NA
	• Fireman's Grounding Switch	NA	NA
	• Lift Signage	NA	NA
17.	Standby power supply	Required	D.G. set 100 K.V.A M.R.
18.	Refuge Area		
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19.	Fire Control Room		
	➤ Detector System Panel	NA	NA
	➤ Flow Switch Panel	NA	NA
	➤ PA system Panel	NA	NA
	➤ Batter backup	NA	NA

	➤ Building Floor plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view the deemed compliance of minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2013/194 dated 23/04/2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspection Officer

Name Sunil Chandra

Name

Designation D. S.

Designation