

Form 'H'
FROM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub-rule (1) of rule 35]
GOVT. OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE,
CONNOUGHT PLACE, NEW DELHI -110001

No. F6/dfs/ms/club/2015/w2/372

Dated: 17/03/15

FIRE SAFETY CERTIFICATE

Certified that the **Pitampura Club**, located at **H-4/5, Pitampura, Delhi-110034** comprised of Basement+Ground+2 Upper Floors was issued FSC vide Letter No.F6/DFS/MS/2012/1096 dated 27.03.2012. The premises was re inspected by the officers concerned of this department on 19.01.2015 in the presence of **Mr. J.R.Mehadiratta (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "D" (Assembly) occupancy with effect from...17.03.15...for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on17.03.15.....at New Delhi by.


(SANTOSH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:

1. Joint C.P (Lic.) 1st Floor, PS Defence Colony, New Delhi.
2. Mr. J.R. Mehadiratta, Pitampura Club, H.-4/5, Pitampura, Delhi-110034.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.



INSPECTION REPORT

Name & address of the building: Pitampura Club, located at H – 4/5, Pitampura, Delhi – 110034.

1. Type of Occupancy : Assembly (Basement +Ground + 2 U. Floors)
2. Type of Case : Renewal
3. Details of previous NOC : F.6/DFS/MS/Club/2012/1096
Dated 27/03/2012
4. Fire Safety directives Letter No. : NBC
5. Date of inspection : 19-01-2015
6. Name of the Inspecting Officer : Dy. CFO/WZ, DO (West) & ADO (WP)
7. Name and designation of Officer
from the building side : Sh. J.R. Mehandiratta (Manager)
8. Year of Construction : ...
9. Applicant's letter No. : 44648/joint c.p./Lic(H)dated new Delhi 02-12-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 m 5 m 3 m	Provided Provided Provided	MR MR MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	2 2	Provided 4 Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1X150cm&1X125cm 1X150cm&1X125cm	Old Case Old Case	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required NA	Provided NA	MR NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	2m	Old Case	Old case
	f. Door Size	1X2m & 1X1.5m	Old case	Old case

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	12 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	CO ₂ & ABC	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Ground Floor	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Each Floor	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR

12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	900lpm & 240lpm Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank cap.	20,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2012/1096 Dated 27-03-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Sh Sumil Chaudhary

Designation

AD/OP

Designation

Defo

