

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/2015/W2/315

Dated: 10/3/15

FIRE SAFETY CERTIFICATE

Certified that the **PWD Housing Complex** located at **Shalimar Bagh, Delhi- 110088** comprised of 3 Blocks of Stilt + 8 upper Floors & 2 Blocks of Ground +06 Upper Floors except community hall was issued FSC vide Letter No. F6/DFS/MS/2011/2617 Dated 20-10-2011. The premises was re inspected by the officers concerned of this department on 20-01-2015 in the presence of Sh. Vashishit (SDO) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "A"(Residential) with effect from 10/3/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ....10.3.15..... at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer

Copy to:

1. The Sub Divisional Engineer, Provincial Sub Division No-1, PWD B&R Branch, Haryana Bhawan, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The community hall shall not be used for any purpose till clearance is obtained from this department

## INSPECTION REPORT

1. Name & address of the building: PWD Housing Complex Shalimar Bagh, Delhi – 110088.
2. Type of Occupancy : Class –A, Residential 5 Blocks (3 BL. Stilt + 8Upper Floors) (09 BL Stilt +6 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2011/2617 dated 20/10/2011
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2006/3409 dated 21/11/2006
6. Date of inspection : 20-01-2015
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer  
from the building side : Sh. Vashishit(SDO)
9. Year of Construction : 2010
10. Applicant's letter No. : 10173 dated 23/12/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	Directive Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	24m	Provided	MR
	• Gate width	6m	Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1X1.20 + 1X1.37m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	Old Case	Old Case	Old Case
	f. Door Size	Old Case	Old Case	Old Case

3.	Compartmentation				
	• Fire check door	NA	NA		
	• Sealing of electrical shafts	Required	Provided	NA	✓
	• Fire Rating of shaft door	Required	Provided	MR	✓
	• Water Curtain	NA	NA	NA	
	• Fire Dampers	NA	NA	NA	
4.	Smoke managements System				
	• Basements	NA	NA	NA	
	• Upper floors	NA	NA	NA	
5.	Fire Extinguishers				
	• Total numbers	44 nos.	Provided	MR	✓
	• Types	CO <sub>2</sub> & ABC	Provided	MR	
	• IS marking	ISI marked			
6.	First - Aid Hose Reels				
	• Total numbers on each floor	1	Provided	MR	
	• Length of hose reel-hose	30 m	Provided	MR	
	• Nozzle diameter	5 mm	Provided	MR	
7.	Automatic fire detection and alarming system				
	• Type of detectors	NA	NA	NA	
	• Location of Main Panel	NA	NA	NA	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location	NA	NA	NA	
8.	MOEFA	Required	Provided	NA	
9.	Public Address System	Required	Provided	MR	✓
10.	Automatic Sprinkler System			MR	✓
	• Basements	NA	NA	NA	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11.	Internal Hydrants				
	• Size of riser/down-comer	150 mm	Provided	MR	
	• Number of hydrants per floor	1	Provided	MR	
	• Hose Box	1	Provided	MR	
12.	Yard Hydrants				
	• Total number of hydrants	Required	Provided	MR	
	• Hose Box	Required	Provided	MR	

13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw of connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	2.00.000 liter	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		25, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

20.	Special Fire Protection Systems for Protection of special Risks, if any;	Manual CO2 Flooding for HT & LT	Provided	MR
-----	--	---------------------------------	----------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2011/2617 dated 20/10/2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:-The community hall has no fire safety arrangement & not cleared by this department.

Signature of the Inspecting Officer



Signature of the Inspecting Officer

Name

Uday Kir Singh

Name

Designation

ASD /wp

Designation

ASD /wp

