

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. *FG/DFSM/School/2015/102/385*

Dated: *18/3/15*

**FIRE SAFETY CERTIFICATE**

Certified that the Rajkiya Sarvodaya Kanya Vidyalaya at East Vinod Nagar, Delhi - 91, comprised (Six Blocks) of ground plus one upper floor owned/occupied by Rajkiya Sarvodaya Kanya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the circular No.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officer concerned of this department on 11.03.15 in the presence of Smt.Ruma Jhuma Banik (Vice-Principal), of the school and that the ground & first floor of the six building blocks is fit for occupancy class 'B' "Educational Building' with effect from .....*18/3/15*... for a period of three years, subject to conditions printed overleaf.

Issued on.....*18/03/15*.....at New Delhi by



(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

*G.C. Misra*

To,  
The H.O.S  
Rajkiya Sarvodaya Kanya Vidyalaya  
East Vinod Nagar, Delhi -91

Copy:-

1. The Dy. Director of Education (GNCT of Delhi)  
D-Block, Anand Vihar, Delhi.
2. The Principal  
Rajkiya Sarvodaya Bal Vidyalaya  
East Vinod Nagar, Delhi -91

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N16

1. Name & address of the building : R.S.K.V at East Vinod Nagar, Delhi-91.
2. Building is comprised of : Ground +1, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/FS/2011/3298 to 3398  
dated 1.3.11
7. Date of Inspection : 11.03.2015
8. Name of the Inspecting officers : ADO Suresh Singh
9. Name and designation of Officer:  
from the building side : Smt.Ruma Jhuma (Vice -Principal)
10. Year of Construction : 2011-2014
11. Applicant's letter No : RSKV/EVN/83 dated 03.03.15

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remark
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 Mtrs.	15 Mtrs.	M/R
		4.5 Mtrs,	4.5 Mtrs	MR
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	10 Nos.	10 Nos.	MR
	A –Block	01 No.	01 No.	MR
	B – Block	02 Nos.	02 Nos.	MR
	C- Block	01 No.	01 No.	MR
	D- Block	02 Nos.	02 Nos.	MR
	E-Block	03 Nos.	03 Nos.	MR
	F-Block	01 No.	01 No.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.5 M	MR
	A –Block	1.5 M	1.5 M	MR
	B – Block	1.5 M	1.3 & 1.5 M	MR
	C- Block	1.5 M	1.5 M	MR
	D- Block	1.5 M	1.4 & 1.5 M	MR
	E-Block	1.5 M	1.3,1.4 & 1.5 M	MR
	F-Block	1.5 M	1.6 M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A



5. Details of Previous NOC letter : Nil
- 6 Fire Safety direction letter No : F.16/Estate/CC/FS/2011/3298 to 3398  
dated 1.3.11
- 7 Date of Inspection : 11.03.2015
- 8 Name of the Inspecting officers : ADO Suresh Singh
- 9 Name and designation of Officer:  
from the building side : Smt.Ruma Jhuma (Vice -Principal)
- 10 Year of Construction : 2011-2014
- 11 Applicant's letter No : RSKV/EVN/83 dated 03.03.15

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remark
1	Access to building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 Mtrs.	15 Mtrs.	M/R
		4.5 Mtrs,	4.5 Mtrs	MR
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	10 Nos.	10 Nos.	MR
	A -Block	01 No.	01 No.	MR
	B - Block	02 Nos.	02 Nos.	MR
	C- Block	01 No.	01 No.	MR
	D- Block	02 Nos.	02 Nos.	MR
	E-Block	03 Nos.	03 Nos.	MR
	F-Block	01 No.	01 No.	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	1.5 M	1.5 M	MR
	A -Block	1.5 M	1.5 M	MR
	B - Block	1.5 M	1.3 & 1.5 M	MR
	C- Block	1.5 M	1.5 M	MR
	D- Block	1.5 M	1.4 & 1.5 M	MR
	E-Block	1.5 M	1.3,1.4 & 1.5 M	MR
	F-Block	1.5 M	1.6 M	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire rating of shaft door</li> <li>Water curtain</li> <li>Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floor</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

5.	Fire Extinguishers			
	• Total numbers	13 Nos.	16 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A



N/8

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire extinguishers provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the circular no.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 is recommended to grant Fire Safety Certificate.

*Singh*  
11.3.15

Signature of the Inspecting Officer  
Name:-Suresh Singh  
Designation:-ADO (Shah.)

DO(ED)

*Submitted for approval please.*

*Ningh*  
12/31/15