

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.

F6/DFS/MS/2015/N22/403

Dated:

20/03/15

FIRE SAFETY CERTIFICATE

Certified that the Royal Community Hall Minocha Yogic Shiksha & Sanskriti Nyas, Mandawali Fazalpur, opp. Bathla CGHS, Patparganj, IP Extension, Delhi, comprised of basement, ground plus one upper floor owned/occupied by Royal Community Hall, have complied with the fire prevention and fire safety requirements in accordance with recommendation letter no F6/DFS/MS/BP/98/575 dated 20.03.1998 issued by the Delhi fire Service and verified by the officers concerned of Fire Service on dated 08.03.2015 in the presence of Gen. Secretary and found that the building is fit for occupancy class D 'Assembly (Banquet Hall)' with effect from20/3/15 for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....20/3/15.....at New Delhi by



(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

o/c Shms

Copy to-

1. The Deputy Health Officer,
East Delhi Municipal Corporation,
Health Department, Shahdara (South) Zone
Karkardooma, Shahdara, Delhi-32.
2. The Gen. Secretary,
Royal Community Hall,
Minocha Yogic Shiksha & Sanskriti Nyas,
Mandawali Fazalpur, opp. Bathla CGHS, Patparganj, IP Extension, Delhi

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Royal Community Hall (Minocha Yogic Shiksha & Sanskriti Nyas) at Mandawali Fazalpur, opp. Bathla CGHS, Patparganj, IP Extension, Delhi
2. Building is comprised of : B+G+1
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F6/DFS/MS/BP/98/575 dated 20.03.1998
7. Date of Inspection : 08.03.2015
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer
from the building side : Secretary
10. Year of Construction : 1998
11. Applicant's letter No : Nil

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement /NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	24 m	MR
	Gate width	4.5 m	5 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	02 no.	MR
	Basement	2 no.	02 no.	MR
	b. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR
	Basement	1.5 m	1.5 m each	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	2 m	2m,1.5m,1.5m	MR
i. No. of door	2 no.	3 no.	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	Required	Provided	MR
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Ventilated	Ventilated	MR
	Upper floor	Ventilated	Ventilated	MR

5.	Fire Extinguisher				
	Total numbers types IS marking	06 no.	06 no.	MR	
		CO ₂ & ABC	CO ₂ & ABC	MR	
		ISI marked	ISI marked	MR	
6	First-aid-Hose Reels.				
	Total numbers of each floor Length of hose reel hose Nozzle diameter	1 no.	1 no.	MR	
		30 m	30 m	MR	
		5 mm	5 mm	MR	
7	Automatic fire detection and alarming system.				
	Type of detectors	N.A.	N.A.	N.A.	
	Location of main panel	N.A.	N.A.	N.A.	
	Location of repeater panel	N.A.	N.A.	N.A.	
	Alternate source of power	N.A.	N.A.	N.A.	
	Hooters's location	N.A.	N.A.	N.A.	
8	MOEFA	N.A.	N.A.	N.A.	
9	Public address System.	N.A.	N.A.	N.A.	
10	Automatic Sprinkler System.				
	basement upper floor sprinkler above false ceiling	Required	Provided	MR	
		N.A.	N.A.	N.A.	
		N.A.	N.A.	N.A.	
11	Internal Hydrants				
	size of riser/down-comer	N.A.	N.A.	N.A.	
	Total no. of hydrants each floor	N.A.	N.A.	N.A.	
	Hose Box per floor	N.A.	N.A.	N.A.	
12	Yard Hydrants.				
	Total number of hydrants	N.A.	N.A.	N.A.	
	Hose Box	N.A.	N.A.	N.A.	
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 				
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
			900 LPM	900 LPM	MR
			40 m	40 m	MR
			Required	Provided	MR
			Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	10,000 Liters	Provided	MR
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	12,500 Liters	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

S Singh
8.3.15

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO

DO (EAST)

*As per approval dated 20.3.98, bldg was proposed B+G+FF+SF, but y
It is only B+G+FF. later to not build up to 2nd floor.*

Submitted for approval please.

By CFO (NO2)

H Singh
12/31/15