

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in

No F6/DFS/MS/2015/1102/350

Dated 12/03/15

FIRE SAFETY CERTIFICATE

Certified that the **Unique Identification Authority of India (UIDAI), AADHAR** located at **Ground floor, Pragati Maidan Metro Station, Pragati Maidan, New Delhi** comprised/ **Ground + Metro Station + 3 levels** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 24-02-2015 in the presence of Sh. A.K. Sharma, Section Officer (Admn) that the premises is fit for occupancy of class **"Business Building"** as above for Ground floor only with effect from 13/03/15 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on13.03.15..... at New Delhi by.


(Dr. G.C.Misra)
Chief Fire Officer
Delhi Fire Service
Ph - 011-23414333

Copy to:-

1. Sh. A.K.Sharma,
Section Officer (Admn),
Unique Identification Authority of India (UIDAI),
Pragati Maidan Metro Station, Pragati Maidan, New Delhi
2. Sh. Suman Kumar,
Asstt Director General (Admin),
Unique Identification Authority of India (UIDAI),
Pragati Maidan Metro Station, Pragati Maidan, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : **Unique Identification Authority of India (UIDAI), AADHAR** located at **Pragati Maidan Metro Station, Pragati Maidan, New Delhi.**
2. Type of Occupancy : **Business Building at Ground Floor only**
3. Type of Case : Fresh
4. Details of previous NOC : F6/MS/DFS/2013/NDZ/577 dated 19/07/2013 (Pragati Maidan Metro Station)
: F.6/DFS/MS/Metro/2014/NDZ/965 dated 31/07/2014 (Gr. + 3 Levels), DFCCIL
(Existing Metro Station, Pragati Maidan)
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2011/375 dated 24/02/2011
6. Date of inspection : 24/02/2015
- 7 Name of the Inspecting Officer : Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Sh. A.K. Sharma, Section Officer (Admn)
- 9 Year of Construction : 2008
10. Applicant's letter No. : F.No. A-11018/7/2010/Adm/UIDAI (RO-Delhi) dated 20/02/15.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 Mtr.	12 Mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	6 Mtr.	6 Mtr.	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR

	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.50 Mtr.	2.0 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	12 Nos.	15 Nos.	MR
	• Types	CO ₂ & Wco ₂	CO ₂ & Wco ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	At G. floor	At G. floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	At Gr. floor	At Gr. floor	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	100 MM	100 MM	MR

	<ul style="list-style-type: none"> Number of hydrants per floor 	02	02	MR
	<ul style="list-style-type: none"> Hose Box 	02	02	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	02	02	MR
	<ul style="list-style-type: none"> Hose Box 	02	02	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	2280 LPM	2280 LPM	MR
	<ul style="list-style-type: none"> Head of main pump 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Number of main pumps 	01	01	MR
	<ul style="list-style-type: none"> Jockey pump out put 	220 LPM 2 Nos.	220 LPM 2 Nos.	MR
	<ul style="list-style-type: none"> Jockey pump head 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Standby Pump out put 	2280 LPM	2280 LPM	MR
	<ul style="list-style-type: none"> Standby Pump Head 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> auto Starting/Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump 	900 LPM	900 LPM	MR
	<ul style="list-style-type: none"> Head of the pump 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump 	Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	2,00,000 ltr.	2,00,000 ltr.	MR
	<ul style="list-style-type: none"> Draw of connection 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 Ltr.	20,000 Ltr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA
17	Standby power supply	Required	Provided	MR

18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

It is also submitted that fire fighting system is common and maintained by DMRC.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

M.K. Sharma

Name :- M.K. Sharma
Designation :- ADO (CC)

Do (CD)

18/3/15

18/3/15