

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2015/School/WZ/ 442

Dated: 27 / 03 /2015

**FIRE SAFETY CERTIFICATE**

Certified that **Bright Educational Society, (Nursery School), B – Block, Main Road , Derawala Nagar Delhi-110009** comprised of **Basement + Ground + One Upper floor** owned / occupied by **Bright Educational Society, B- Block , Derawala Nagar Delhi -110009**, has already been issued fire safety certificate **vide letter no. F6/DFS/MS/2014/School/WZ/480 dated 16/04/2014**. The premises was re-inspected by the officer from this department on dated **03/03/2015** in the presence of **Madam Bhavina** and found to be **comprised of basement + ground + two upper floors**. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **27/03 /2015** for a period of **three years**, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The basement shall be used as per building bye laws.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 27/03/15 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. The Principal, Bright Educational Society, (Nursery School), B – Block, Main Road , Derawala Nagar Delhi-110009.
2. The Director of Education, Old Secretariat, Delhi



## INSPECTION REPORT

**( Basement + Ground + Two Upper Floors)**

1. Name & address of the building : Bright Educational Society, Nursery School, B – Block,  
Derawala Nagar, Delhi
2. Type of Occupancy : **Educational**
3. Type of Case : **Addition of one floor**
4. Details of previous NOC : F6/ DFS/MS/2014/School/WZ/480 dated 16/04/2014
5. Fire Safety directives letter No : Director of education
6. Date of inspection : 03/03/2015
7. Name of the Inspecting Officers : DO( NW)
8. Name and designation of officers  
from the building side : Madam Bhavina
9. Year of Construction : 2010 & 2015
10. Applicant's letter No. : Nil dated 18/ 02 /2015

Plot area:- 1000 sq yds, Covered area 332.61 No of Students 400, Classrooms:- 15

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	M/R ✓
	• Gate width	Accessible	Accessible	M/R ✓
	• Width of internal road	--	--	--
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02 stairs, One ramp	M/R ✓
	• Basements	02	02 stairs, One ramp	M/R ✓
	b. Width of staircases			
	• Upper Floors	2 x 1.5 mtr	2 x 1.5 mtr	M/R ✓
	• Basements	2 x 1.5 mtr and one ramp	Provided	M/R ✓
	c. Protection of exits			
	• Fire check door	R	P	M/R ✓
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace	--	--	--
	g. Width of Corridor	--	--	--
	h. Door Size	1 mtr	1.10 mtr (Two exit in each room)	M/R ✓
3	<b>Compartmentation.</b>			
	• Fire check door	R	P	M/R ✓

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	--	--	--
		--	--	--
		--	--	--
		--	--	--
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	09 ABC	09	M/R
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ISI marked	06 ABC, 03 WCO <sub>2</sub>	M/R
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>		Yes	M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	01	P	M/R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	—	—
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	—	—
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	R	P	M/R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	R	P	M/R
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	—	—	—
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A

13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900 LPM	P	M/R
		40 M	P	M/R
		R	P	M/R
		R	P	M/R
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	--	--	--
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10000 ltr	10000 ltr	M/R
15	<b>Exit Signage.</b>			
		--	--	--
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby power supply</b>			
		--	--	--
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room</b>			

	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2014/School/WZ/480 dated 16/04/2014** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

*De FO (W2)*

Signature of the Inspecting Officer

Name

Designation

*Deigh*

*12/3/15*

*De FO (W2)*

*194/DFS/WZ*