

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. *F6/DFSI(MS) Hospital/2015/52/463*

Dated: *27/03/15*

FIRE SAFETY CERTIFICATE

Certified that M/S Charak Palika Hospital, Moti Bagh, New Delhi, comprised of basement(storage only), ground plus three upper floors, owned occupied by New Delhi Municipal Council have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of this department on 17-03-2015 in the presence of Sh. Sajan Kumar (Fire Officer) and found that the said premises is fit for occupancy class Institutional Building (Hospital) with effect from*27/03/2015* for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued ...*27/03/2015* at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

ote
g

Copy to:-

Sh. Ajay Kumar, Fire Officer,
Fire Department, NDMC,
Palika Kendra, New Delhi-110001.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

M/2

INSPECTION REPORT

1. Name & address of the building : Charak Palika Hospital, Moti Bagh, New Delhi.
 2. Building comprised of : B+G+3.
 3. Type of Occupancy : Institutional.
 4. Type of Case : New Case.
 5. Details of Previous NOC : Nil.
 6. Fire Safety direction letter No : Nil.
 7. Date of Inspection : 17.03.15.
 8. Name of the Inspecting Officers : Vedpal (ADO).
 9. Name and designation of Officer from the building side : Sh. Sajan Kumar, Fire Officer, NDMC.
 10. Year of Construction : 1979.
 11. Applicant's letter No : No.388/Fire/D/2015, dated 02.03.15.

S.No	Minimum Standards on fire prevention and fire safety under Rule33.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	12m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	03nos.	02nos.+3ramps	MR
	Basement	01no.	01no.ramp	MR
	B. Width of Staircases	.		
	Upper Floor	1.5m/02m	1.5,1m&ramps=2m,1.5m & 1.5m	MR
	Basement	1.5m	1.5m ramp	MR
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	1no.+1no. ramp	MR
g. Width of Corridor	2 m	2 m	MR	
h. Door Size	1.5 m	1.5m	MR	
3	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fans provided	MR
	Upper floor	15 a/c per hour	Exhaust fans provided	MR

Charak Palika Hospital, Moti Bagh, New Delhi.

5.	Fire Extinguisher			
	Total numbers	50 nos.	50 nos.	MR
	Types	ABC&WCO ₂	ABC&WCO ₂	MR
	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	03nos.	03nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat & Smoke	Heat & Smoke	MR
	Location of main panel	Ground Floor	Ground Floor	M R
	Location of repeater panel	Fire Control Room	Fire Control room	M R
	Alternate source of power	Required	Provided	M R
	Hooters	On each floor	On each floor	M R
8	MOEFA	Required	Provided	M R
9	Public address System.	Required	Provided	M R
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	M R
	Number of hydrants per floor	03Nos.	03Nos.	M R
	Hose Box	03Nos.	03Nos.	M R
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	1620lpm	1620lpm	MR
	➤ Head of Main Pump	60m	60m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	180 LPM	180LPM	MR
	➤ Jockey pump head	60m	60M	MR
	➤ Standby pump out put	1620 LPM	1620LPM	MR
	➤ Standby pump Head	60m	60m	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	➤ Terrace Level	N.A.	04nos.	N.A.
	➤ Discharge of pump	N.A.	900LPM(each)	N.A.
	➤ Head of the Pump	N.A.	40m(each)	N.A.
	➤ Power supply	N.A.	Provided	N.A.
	➤ Auto Starting of pump	N.A.	Provided	N.A.

M/4

Charak Palika Hospital, Moti Bagh, New Delhi.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50000Liters	Provided	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	10000Liters.	15000Liters	MR
15	Exit Signage.	Required	Provided	M R
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	320KVA	M R
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	Required	Provided	MR
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	Required	Provided	MR
	Battery backup	Required	Provided	MR
	Building Floor Plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special Risks, if any:	Required	Provided ABC Type fire Extinguishers in HT < Panels	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for kind consideration please.



D.O. (South)

[Handwritten signature]
28/3/15

[Handwritten signature] 28/3/15
Signature of the Inspecting Officer
Name: Vedpal
Designation: ADO