

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

Fax:- 011-23412593

E-mail ID: [cfohq.dfire@nic.in](mailto:cfohq.dfire@nic.in)


No. F6/DFS/MS/GH/2015/ *N02/263*

Dated *26/02/15*

**FIRE SAFETY CERTIFICATE**

Certified that the **54 Janpath Connaught Place, New Delhi** building is comprised of **Two Block A - Basement + Ground + 3 floor** and **Block -B Ground + 1<sup>st</sup> floor** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 14-02-2015 in the presence of Sh. Sachdeva that the premises is fit for occupancy of class **Assembly Building Group-D of Sub-Division D-5 Restaurant at Ground floor (B-Block) only** with effect from *26/02/15* for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *26/02/15* at New Delhi by.



(Dr. G.C. Misra)  
Chief Fire Officer  
Ph – 011-23414333

*S/C Misra*

Copy to:-

1. Dr. P.K. Sharma, Medical Officer of Health, Health Department, New Delhi Municipal Council Palika Kendra, New Delhi.
2. Sh. Sachdeva, 54 Janpath Connaught Place, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building : 54 Janpath Connaught Place, New Delhi.
2. Type of Occupancy : Business Building A-Block ( B + Gr. + 3 upper floors  
B- Block (Gr. + 1<sup>st</sup> floor ) (Restaurant at Ground floor )
3. Type of Case : Fresh
4. Details of previous NOC : F6/DFS/MS/2012/3115/ dated 27/08/12 (A- Block)
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 14/02/2015
- 7 Name of the Inspecting Officer : Sh.Rajesh Panwar (DCFO/NDZ), Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer  
from the building side : Mr. Sachdeva
- 9 Year of Construction : Old Heritage Building
10. Applicant's letter No. : No. MOH/444/D/CMO(Lic)/SI-V dated 11/02/2015.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9Mtr.	12 mt	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	04	MR
	• Basements	01	01	MR
	b.Width of staircases			
	• Upper floors	1.5 mtr & 1 mtr.	1.52 mt., 1.20 mtr., 1 mtr. & 0.80 mtr.	MR
	Basements	1 mtr.	1 mtr.	MR
	c..Protection of exits			
	• Fire check door	NA	NA	NA

Mar

	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>			
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> </ul>	100mm	100mm	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	02	02	MR
12	Yard Hydrants -			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>○ Ground Level</li> <li>• Discharge of main pump</li> <li>• Head of main pump</li> <li>• Number of main pumps</li> <li>• Jockey pump out put</li> <li>• Jockey pump head</li> <li>• Standby Pump out put</li> <li>• Standby Pump Head</li> <li>• auto Staring/Manual stopping</li> <li>• Pump House Access</li> <li>○ Terrace level</li> <li>• Discharge of pump</li> <li>• Head of the pump</li> <li>• Power supply</li> <li>• Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	450 LPM, 280 LPM	MR
		30 mt	30 mt	MR
		Requried	Provided	MR
		NA	NA	NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Draw of connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	10,000 ltrs	10,000 ltrs	MR

MW

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	Provided	NA
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co <sub>2</sub>	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and the restaurant is at ground floor only.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

Name :- Sh. Rajesh Panwar

Designation :- Dy.CFO (NDZ)

Signature of the Inspecting Officer

Name :- Sh. M.K. Sharma

Designation :- A. D.O. (CC)