

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/MS/DFS/EH/2015/ 52/422

Dated 23/02/15

FIRE SAFETY CERTIFICATE

Certified that the M/S "T Zers" Restaurant (A unit of Four Some Foods Pvt. Ltd) located at 17,Community Centre, Saket, New Delhi-110017 is running at second & third floor of a building, comprised of basement, ground + three upper floors was granted FSC by this department vide letter No.F6/MS/DFS/MS/EH/2011/3618 Dated 19/12/2011. The premises was re- inspected by the officer concerned of this department on 27/02/15 in the presence of Mr. Nayanjyot Singh(Owner) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group – D Assembly Building (Restaurant) with effect from ~~23/12/15~~ 23/2/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~23/12/15~~ 23/2/15 at New Delhi by.



(Dr. G.C.Misra)  
Chief Fire Officer  
Tel:- 011-23414000

ok [Signature] Ado (Rep)

Copy to ;

Director  
T'Zers ( Restaurant)  
A Unit of Foursome Foods Pvt Ltd  
17,Community Centre,PVR Saket,  
New Delhi-110017

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building:- M/S T Zers Restaurant (A Unit Of Four Some Foods Pvt.Ltd)

17, Community Centre, PVR Saket, New Delhi-110017

2. Type of occupancy:- Assembly, Group – D, Restaurant

3. Type of case:- Renewal

4. Details of previous NOC:-F6/DFS/MS/EH/2011/3618 Dated 19/12/2011

5. Fire safety directives No.- Nil

6. Date of inspection:-27/02/2015

7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)

8. Name & designation of officer From the building side:- Mr. Rajesh ( Accountant)

9. Year of construction:- 1988.

10. Applicant's letter no:- Nil Dated 17/01/2015

Building is comprised of Basement, Ground + Three Upper Floors Restaurant is running on second Floor only.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	Required	24 Mtr Provided	MR
	2) Gate width	Required	1.5 mtr Resturant gate provided	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	1 Nos	1 Nos	MROld Case
	2. Basements	1 Nos	1 Nos	MROld Case
	B. Width of staircase			
	1. Upper floors	1.25	1.19 mtrs	MROld Case
	2. Basements	1.25	1.19 mtrs	MROld Case
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01Nos	Provided	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtrs	1.5 Mtrs	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust Fan	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	12Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR



<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01Nos	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01 no	Provided	MR
	3) Hose box	01 no	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	450 LPM & 180 LPM	Provided	MR
	b) Head of pump	40 mtrs	40 mtrs & 40 mtrs	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000ltrs	5,000Ltrs	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR




	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2011/3618 dated 19/12/2011, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.

  
12/3/15

Signature of the inspecting officer

Name :- D.B. Mukherjee.

Designation :- Assistant Divisional Officer.