

## FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
 NEW DELHI

No. FG/DFS/MS/2015/EH/426Dated: 24/3/15FIRE SAFETY CERTIFICATE

Certified that the **Punjabi By Nature (A unit of A R Fisheries Pvt. Ltd.)** located at **TF - 06, City Square Mall, Shivaji Palace, III Floor, Raja Garden, New Delhi - 110027** was issued FSC vide Letter No. F6/DFS/MS/2012/EH/515 dated 16-02-2012. The premises was re inspected by the officers concerned of this department on 27-02-2015 in the presence of Mr. Tarak Nandy Mazumder (Sr. General Manager) and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 24/3/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/3/15..... at New Delhi by:



Santokh Singh  
 Chief Fire Officer  
 Delhi Fire Service

Copy to:

1. Sh. Tarak Nandy Mazumder (Sr. GM),  
 Punjabi By Nature (A unit of A R Fisheries Pvt. Ltd.),  
 TF - 06, City Square Mall,  
 Shivaji Palace, III Floor, Raja Garden, New Delhi - 110027.

OK  
 Any

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010; form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: Punjabi By Nature (A unit of A R Fisheries Pvt. Ltd.), TF – 06, City Square Mall, Shivaji Palace, III Floor, Raja Garden, New Delhi – 110027.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situating in Mall already issued NOC vide letter no. F6/DFS/MS/2014/WZ/523 dated 28-04-2014)
4. Details of previous NOC : Letter No. F6/DFS/MS/2012/EH/515 dated 16-02-2012.
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 27-02-2015
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer  
from the building side : Mr. Tarak Nandy Mazumder (Sr. GM)
9. Year of Construction : 2006
10. Applicant's letter No. : Nil Dated 02-01-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access of building (Mall)</b>			
	• Road width	30 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	<b>Number, width, Type &amp; Arrangements of exits (Mall)</b>			
O	a. Number of staircases			
	• Upper floors	3	Provided	MR
	• Basements	5	Provided	MR
	b. Width of staircases			
	• Upper floors	1X1.5m & 2x1.25m	Provided	MR
	• Basements	1X1.5m & 4 X 1.25m	Provided	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x2m	Provided	MR
3.	<b>Compartmentation</b>			

	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	06 nos.	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	DCP & CO <sub>2</sub>	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	1	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Smoke	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System: <b>Common with the Mall</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11.	Internal Hydrants: <b>Common with the mall</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	150 mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NR	NR	NR
13.	Pumping Arrangements: <b>Common with the mall</b>			
	<ul style="list-style-type: none"> <li>• Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>• Discharge of main pump</li> </ul>	2850 lpm	Provided by mall	MR
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	60 m	Provided by mall	MR

	➤ Number of main pumps	1	Provided by mall	MR
	➤ Jockey pump out put	180 lpm	Provided by mall	MR
	➤ Jockey pump head	60 m	Provided by mall	MR
	➤ Standby Pump out put	2850 lpm	Provided by mall	MR
	➤ Standby Pump Head	60 m	Provided by mall	MR
	➤ Auto Staring/Manual stopping	Required	Provided by mall	MR
	➤ Pump House Access	Required	Provided by mall	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided by mall	MR
	➤ Head of the pump	40 m	Provided by mall	MR
	➤ Power supply	Required	Provided by mall	MR
	➤ Auto starting of pump	Required	Provided by mall	MR
14.	<b>Captive water Storage for fire fighting: Common with the mall</b>			
	• Under ground tank capacity	NA	1,00,000 litres	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10,000 litres	30,000 Litres Provided	MR
15	Exit Signage	Required	Provided	MR
16.	<b>Provision of Lifts: Common with the Mall</b>			
	➤ Pressurization of Lift Shaft	NR	NR	NR for Restaurant
	➤ Pressurization of lift lobby	NR	NR	NR for Restaurant
	➤ Communication in lift Car	NR	NR	NR for Restaurant
	➤ Fireman's Grounding Switch	NR	NR	NR for Restaurant
	➤ Lift Signage	NR	NR	NR for Restaurant
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NR	Provided	NR
	➤ Location	NR	Open Terrace	NR
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA

	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2012/EH/515 dated 16-02-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name **MUKESH VERMA**

Designation **ADO (MN)**

Signature of the Inspecting Officer

Name

Designation