

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2015 /w2/477

Dated: 31/03/2015

FIRE SAFETY CERTIFICATE

Certified that PUSHPA DEVI BAGRODIA DHARAMSHALA located at PSP Area- 3, Sector- 5, Rohini, Delhi-110085 comprised of Ground + Two Upper Floors owned/occupied by Purushottam D Nagarwal, has already been issued fire safety certificate vide letter no. F6/DFS/MS/2012/773 dated 05/03/2012 deemed to have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 13/03/2015 in the presence of Sh. D. P. Tyagi (CSO) & that the building / premises is fit for occupancy Class A Residential building with effect from 31 / 03 / 2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 31/03/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:-

1. The Manager, PUSHPA DEVI BAGRODIA DHARAMSHALA located at PSP Area- 3, Sector- 5, Rohini, Delhi 110085
2. The Joint Commissioner of Police; Lic. Branch, 1st floor, PS Defence Colony, Delhi

1. Name & address of the building : Pushpa Devi Bagrodia Dhasamshala, PSP Area-03, Sec-5
Rohini, Delhi-110085
2. Type of Occupancy : **Residential building Group A**
3. Type of Case : Renewal case (Old Building)
4. Details of previous NOC : F-6/DFS/MS/2012/773 dated 05/03/2012
5. Fire Safety directives letter No : Nil
6. Date of inspection : 13/03/2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Sh. D. P Tyagi (CSO)
9. 9. Year of Construction : 1999 (Old building)
10. 10. Applicant's letter No. : RGCIRC/2015 dated 15/01/2015

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	P	M/R
	• Gate width	4.5 m	P	M/R
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	--	--	--
	• Upper Floors	01	01	M/R
	• Basements	--	--	--
	b. Width of staircases	--	--	--
	• Upper Floors	1.5 mtr	1.5 mtr	M/R
	• Basements	--	--	--
	c. Protection of exits	--	--	--
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace	--	--	--
	g. Width of Corridor	--	--	--

	h. Door Size	1 mtr	1 mtr	M/R
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	20	20	M/R
	• Types	ISI marked	10 ABC & 10 CO2	M/R
	• IS marking		Yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	1 ✓	One at each floor & one at terrace provided	M/R
	• Length of hose reel hose		P	M/R
	• Nozzle diameter		30 m 5 mm	Yes
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	R	P	M/R
9	Public Address System.	R	P	M/R
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	P	M/R
	• Number of hydrants per floor	One at each floor & one at terrace provided	P	M/R

	<ul style="list-style-type: none"> • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F-6/DFS/MS/2012/773 dated 05/03/2012** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Defto (4/22)

Signature of the Inspecting Officer

Name

Designation

Pushp
20/3/15
Defto (4/22)