

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO. F6/DFS/MS/Club/2015/NP2/453

DATED: 27/3/15

FIRE SAFETY CERTIFICATE

Certified that the Riverside Sports & Recreation Club at Club Avenue, Mayur Vihar-1 Extn., Delhi-91, owned/occupied by Riverside Sports & Recreation Club, comprised of basement, ground plus two upper floors was granted fire safety certificate vide letter no. No.F.6/DFS/MS/Club/2012/1817 dated 21.05.2012. The Riverside Sports & Recreation Club building was inspected by the officer concerned of this department on 28.02.2015 in the presence of Sh. Angad Chauhan, Asstt. Manager of club and found that the club building has been deemed to comply with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of condition under rule 38 that the Basement+ GF+FS+SF of building is fit for occupancy Group D "Club Building" with effect from ...27/3/15... for a period of three years, printed overleaf.

Issued on27/3/15..... at New Delhi by



(Dr. G. C. Misra)
Chief Fire Officer
Ph.011-23414333



To,
The Asstt. Commissioner (Club),
GNCT of Delhi, L&N Block,
Vikas Bhawan, I.P. Estate,
New Delhi-110002.

Copy to:-
The Asstt. Manager
Riverside Sports & Recreation Club
Club Avenue, Mayur Vihar-1 Extn.,
Delhi-91.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. All comments/ directions of the Licensing Department shall always be permitted and followed.
8. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

2/12

1. Name & address of the building : Riverside Sports & Recreation Club at Club Avenue, Mayur Vihar-1 Extn., Delhi-91.
2. Building comprised of : B,G+2 Upper Floor
2. Type of Occupancy : Assembly (Club Building)
3. Type of Case : Renewal
4. Details of Previous FSC : F.6/DFS/MS/Club/2012/1817 dated 21.05.12
5. Fire Safety directives No : F.6/DFS/MS/BP/97/481 dated 1/05/97
6. Date of Inspection : 28.02.15
7. Name of the Inspecting Officer : DO Virendra Singh
8. Name of the designation of Officer
From the building side : Sh.Angad Chauhan (Assitt. Manager)
9. Year of Construction : 1999
10. Applicant's letter No : RSRC/FF/2015 dated 19.01.2015

	Minimum Standards on fire prevention and fire safety U/R33	Old building Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	12 Mtrs	30 Mtrs.	MR
	• Gate width	4.5 Mtrs.	6 Mtrs.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 No.	❖ 02 Nos.	MR
	• Basement	02 Nos.	01 No +Ramp	MR
	b. Width of Staircases			
	• Upper Floor	1.25 M	1.4 M & 80 CM	MR
	• Basement	1.25 M	1.4 M & ramp of 80 CM	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1 No.	1 No.	MR
	e. Width of Corridor	1.5 Mtrs	1.5 Mtrs	MR
	f. Door Size	2.0 Mtr. & 1.0 M	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Provided	MR
5.	Fire Extinguisher			
	• Total numbers	15 nos.	26 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	• Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR

❖ One staircase of 80 CM is up to first floor only.


7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters's location	N/A	N/A	N/A
8	MOEFA	Required	provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	Not Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose Box	01 no.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the Pump	60 Mtrs	60 Mtrs.	MR
	➤ Power supply	Auto	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 Ltrs.	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	12,500 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A

2/14

		Required	Provided	MR
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.
In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as required under the rules. The fire safety certificate issued vide letter no.F.6/DFS/Club/2012/1817 dated 21.05.12 is recommended.

Submitted please.


Signature of the Inspecting Officer
Name: Virendra Singh
Designation: DO(ED)