

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/GH/2015/427



Dated :--24/3/15--

**FIRE SAFETY CERTIFICATE**

Certified that the **Shiva Intercontinental** located at **8477-78, Arakshan Road, Pahar Ganj, New Delhi**. comprised of **Basement, Ground +4 Upper Floors** having **39 guest rooms (Basement was found empty, Ground floor has 03 guest rooms + reception + office, First to fourth floor has 09 guest rooms at each floor, terrace floor was sealed)** was granted NOC by this department vide letter No.F6/DFS/MS/2012/GH/1536 dated **27/04/2012**. The premise was re-inspected by the officer concerned of this department on **13/03/15** in the presence of **Mr. Naresh Kapoor (Proprietor)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 for 39 guest rooms at ground to fourth floor as above and terrace sealed** with effect from **24/3/15** -- for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued **24/3/15** at New Delhi by.

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph:- 011-23414333

- Copy to: (1) The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi.   
(2) The Manager, Shiva Intercontinental,   
8477-78, Arakshan Road, Pahar Ganj, New Delhi.

**Conditions:-**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

- 11/9 -  
**INSPECTION REPORT**

1. Name & address of the building:- Shiva Intercontinental, 8477-78, Arakshan Road, Pahar Ganj, New Delhi.
2. Type of occupancy:- Residential Group A-1 (Basement, Ground +4 upper Floors. 39 guest rooms )
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/2012/GH/1536 dated 27/04/2012.
5. Fire safety directives No.- N/A
6. Date of inspection:- 13/03/2015
7. Name of the inspecting officer:- D.O. Gurmukh Singh
8. Name & designation of officer Mr. Naresh Kapoor (Proprietor)  
From the building side:-
9. Year of construction:- Old (2001) h
10. Applicant's letter No:- 3472/Joint.C.P./Lic. (H) dated 20/02/15

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Existing Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	06 mtr.	06 Mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	1 No.	1 No.	MR
	2. Basement	1 No.	1 No.	MR
	<b>B. Width of staircase</b>			
	1. Upper floors	1.25 mtr.	1.25	MR
	2. Basements	1.25 mtr.	1.25	MR
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	1 No.	1 No.	MR
	<b>E. Width of corridor</b>			
	F. Door size	1 mtr.	1 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	15 Nos.	16 No.	MR

h

-17/20-


	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01 No.	01 No.	MR
	2) Length of hose reel hose	30 m	30 mtr.	MR
	3) Nozzle diameter	5 mm	5 mm.	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 Mtr.	30 Mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A

-11/21-

	d) Over head tank capacity	5,000 ltrs.	5,000 Ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A


The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/DFS/MS/2012/GH/1536 dated 27/04/2012, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended

  
 Gurmukh Singh  
 Divisional Officer

DY. CFO (NDZ)



  
 1873