

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. FC/DFB/MS/BNOT/2015/W2/443

Dated: 27/3/15

FIRE SAFETY CERTIFICATE

Certified that the **M/s Gola Ceremonials Banquet Hall** located at **Plot No. 8/39, Kirti Nagar Industrial Area, New Delhi - 110015** in a building comprised of 2 Basements + Ground + 2 Upper Floors owned/ occupied by **M/s Gola Ceremonials Banquet Hall** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 20-02-2015 in the presence of Mr. Naresh Kapoor (Owner) and found that the said building / premises is fit for occupancy class "Assembly" Group D with effect from 27/3/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/3/15 at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: 011 - 23414250.

Copy to:

1. Sh. Naresh Kapoor (Owner),
M/s Gola Ceremonials Banquet Hall,
8/39, Kirti Nagar industrial Area, New Delhi - 15.
2. Dy. Health Officer, Karol Bagh Zone,
NDMC, Public Health Department,
Karol Bagh, New Delhi.

o/c R/23/3

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/Banquet/2015/340 dated 17-02-2015. The building plans are approved by this department vide letter F6/DFS/MS/BP/2012/1692 dated 10-05-2012 from fire safety point of view in r/o industrial building on plot no. 8/39, Kirti Nagar Industrial Area, New Delhi - 110015. Now, Dy. Health Officer, Health Department NDMC, Karol Bagh vide letter no. DHO/KBZ/2014/2568 dated 11-12-2014 has requested to inspect the site from fire safety point of view in r/o Gola Ceremonials Banquet Hall.

INSPECTION REPORT

1. Name & address of the building: Gola Ceremonials Banquet Hall, 8/39, Kirti Nagar, Industrial Area, New Delhi - 110015.
2. Type of Occupancy : Assembly (2 Basements + Ground + 2 Upper Floors)
3. Type of Case : New ✓
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil *As per NBE*
6. Date of inspection : 20-02-2015 ✓
7. Name of the Inspecting Officer : DO (W) & ADO (MN) ✓
8. Name and designation of Officer
from the building side : Sh. Naresh Kapoor (Owner) ✓
9. Year of Construction : 2014 ✓
10. Applicant's letter No. : Nil dated 03-02-2015 ✓

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m ✓	Provided	MR
	• Gate width	5 m ✓	On Main Road	MR
	• Width of internal road	NA ✓	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	Provided ✓	MR
	• Basements	4	Provided ✓	MR
	b. Width of staircases			
	• Upper floors	2X2m, 1X1.5m ✓	2X2m, 151 cm	MR
	• Basements	2X2m, 2X1.5m ✓	2X2m, 2X153cm	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NR	NP	MR

	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X2m, 1X1.5m	GF (8 exits) – 3X2m, 2X121cm, 1X196cm, 1X170cm, 1X190 cm FF (5 exits) – 2X225cm, 1X200cm, 2X162cm. SF (5 Exits) - 2X225cm, 1X200cm, 2X162cm.	MR
3.	Compartmentation			
	• Fire check door	NR	NP	NR
	• Sealing of electrical shafts	NR	NP	NR
	• Fire Rating of shaft door	NR	NP	NR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided ✓	MR
	• Upper floors	Required	Provided ✓	MR
5.	Fire Extinguishers			
	• Total numbers	26 nos.	Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	NP	MR
	• Sprinkler above false ceiling	NR	NP	MR
11.	Internal Hydrants			
	• Size of riser/down-	100 mm	Provided	MR

	comer			
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	70 m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	70 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	Found	MR
	➤ Standby Pump Head	Provided		
	➤ Auto Staring/Manual stopping	70 m	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	Required	Provided	MR
	➤ Head of the pump	900 lpm	Provided	MR
	➤ Power supply	40 m	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA

	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

.....

Signature of the Inspecting Officer
Name
Designation

Mukesh Verma
MUKESH VERMA
ADD (MN)

Signature of the Inspecting Officer
Name
Designation