

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Fax : 011-23412593 E-mail : cfhqfire@nic.in Ph. 011-23414333.


No.F6/DFS/MS/EH/2014/ NP2 1171

Dated :-----05/2/15

**FIRE SAFETY CERTIFICATE**

Certified that the M/s **Indian Grill Company (A Unit of Swagath)** located at **M-48, Connaught Place, New Delhi**. building is comprised of **Ground , Mezzanine + 2 upper floors but restaurant is running on ground & mezzanine floor** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on **28/01/15** in the presence of **Mr. Bhandari (G.M.)** that the premises is fit for occupancy of class **Assembly Building Group-D** at ground & mezzanine floor with effect from ~~---05/2/15---~~ for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....05/2/15..... at New Delhi by.



(Dr. G.C. Misra)  
Chief Fire Officer  
Ph - 011-23414333

Copy to:- (1) Medical Officer of Health,  
New Delhi Municipal Council,  
Palika Kendra, New Delhi.

(2) M/s Indian Grill Company (A Unit of Swagath),  
M-48, Connaught Place, New Delhi.

**Conditions:-**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building:- M/s Indian Grill Company (A Unit of Swagath),M-48,Connaught Place,New Delhi.
2. Type of occupancy:- Group – D Assembly Building (comprised of ground , mezzanine + 2 upper floor restaurant at ground & mezzanine)
3. Type of case:- New
4. Details of previous NOC:- F6/DFS/MS/EH/2006/1381 dated 23/06/06 in the name of ruby Tuesday restaurant
5. Fire safety directives No.- N/A
6. Date of inspection:-
7. Name of the inspecting officer:- D.O. Gurmukh Singh & A.D.O. Manoj Sharma
8. Name & designation of officer From the building side:- Mr. Bhandari (G.M.)
9. Year of construction:- Old.
10. Applicant's letter No:- D/421/MOH(Lic.)/SI-I dated 24/12/14 Restaurant at Ground & Mezzanine floor  
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	9 mtr.	13 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	Required	2 No.	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	103 cms & 89 cms.	103 cms & 89 cms.	MR
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
		Required	one	MR
	<b>E. Width of corridor</b>			
		N/A	N/A	N/A
	<b>F. Door size</b>			
		1.25 mtr. to 1.35 mtr. & 85 cms.	1.25 mtr. to 1.35 mtr. & 85 cms.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A

<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	Required	01 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors (G <sub>2</sub> + M <sub>2</sub> )	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	Required	450 LPM & 180	MR

			LPM	
	b) Head of pump	Required	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	5,000 ltrs.	5,000 Ltr.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

Note :- Earlier Ruby Tuesday Restaurant was granted NOC for the said address (file enclosed)

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate, under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.

*Gurmukh Singh*  
Gurmukh Singh  
Divisional Officer

*Manoj Sharma*  
Manoj Sharma  
Assistant Divisional Officer

Dy. CFO (Vol. 2)