

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F6/DFS/MS/Auditorium/2015/52/242

Dated: 19/02/15

**FIRE SAFETY CERTIFICATE**

Certified that the Auditorium at India International Centre, 40, Max Muller Marg, New Delhi-03, comprised of Ground floor only having total numbers of seats 231, owned/occupied by India International Centre was granted NOC by this department vide letter No. F6/DFS/MS/Auditorium/2010/3296, dated 02-12-2010. The premises was re-inspected by the officer concerned of this department on 06-02-2015 in presence of Sh. Arun Potdar (Chief Maintenance Division) and found that the said auditorium building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly with effect from ...19/02/2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 19/02/2015 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:-

- 1.The Joint. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony  
New Delhi-110049 w.r.t. letter No.58-90/Joint. C.P./Lic.(Amst.) dated 072.01.15.
- 2.Sh.Amod K.Dalela, Administrative Officer, India International Centre, 40, Max Muller Marg,  
New Delhi-03.

**Conditions for the validity of fire safety certificate are overleaf:-**

## CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : Auditorium at India International Centre, 40, Max Muller Marg, New Delhi-110003.
2. Building is comprised of : Ground floor only (231 seats).
3. Type of Occupancy : Auditorium (Assembly Building)
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/Auditorium/2010/3296, Dated-02.12.2010.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection :06.02.2015.
8. Name of the Inspecting Officers: : Vedpal (ADO).
9. Name of the designation of Officer  
from the building side : Sh.Arun Potdar (Chief Maintenance Division).
10. Year of Construction : 1961.
11. Applicant's letter No : No.585-90/Joint CP/Lic.(Amst.), dated 072.01.15.

S.No	Minimum Standards on fire Prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks
1	Access to building			
	Road width	6 m	8 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	Required	Provided	MR
	Upper Floor	Required	Provided	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	1.25m.	1.25m	MR
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace.	Required	1 no Provided	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	1.5m(two)	1.7m(two)+80cm(one)	MR(old Case)
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System. <span style="float: right;">Ventilated</span>			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	Exhaust fan Provided	MR

Note :- Staircase is from adjoining building. No staircase in auditorium. It is ground floor only.



N/27

Auditorium at India International Centre, 40, Max Muller Marg, New Delhi-03.

5.	Fire Extinguisher			
	Total numbers	6 nos.	10 nos.	MR
	Types	WCO <sub>2</sub> .CO <sub>2</sub> , & ABC	WCO <sub>2</sub> .CO <sub>2</sub> , & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers in Auditorium	02nos.	02nos.	MR
	Length of hose reel hose	30 M	Provided	MR
	Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler on stage	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	2nos.	2nos.	MR
	Hose Box	2nos.	2nos.	MR
13	Pumping Arrangements. (Fire fighting system is common for entire complex)			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2280lpm	2280lpm	MR
	➤ Head of Main Pump	75m	75m	MR
	➤ Number of main pumps	02nos.	02nos.	MR
	➤ Jockey pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	75m	75m	MR
	➤ Standby pump out put	2280lpm	2280lpm	MR
	➤ Standby pump Head	75m	75m	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the Pump	35 Mtrs.	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

Auditorium at India International Centre, 40, Max Muller Marg, New Delhi-03.

14	Captive Water Storage for Fire Fighting. (Water storage tanks are common for entire complex)			
	Underground tank capacity	50000 Liters	50000 Liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	20000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	D.G. Set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	Required	2 Co2 fire Ext. 6Kg in projection Room.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/Auditorium/2010/3296 dated 02.12.2010, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

 9/2/15  
Signature of the Inspecting Officer

Name : Vedpal

Designation: ADO