

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in


No. F6/DFS/MS/GH/2015/ *1102/368*

Dated *16/03/15*

FIRE SAFETY CERTIFICATE

Certified that the **52 Janpath Connaught Place, New Delhi** building is comprised of **Ground + Mezzanine + First floor + Second floor + Third floor** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 14-02-2015 in the presence of Sh. B.L. Mangal (GM) that the premises is fit for occupancy of class **Business Building Ground floor + Mezzanine + First floor + Second floor + Third floor** with effect from *16/03/15* for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on*16/03/15*..... at New Delhi by.



(Dr.G.C.Misra)
Chief Fire Officer
Ph – 011-23414333

Copy to:-

1. Dr. P.K. Sharma, Medical Officer of Health, Health Department, New Delhi Municipal Council Palika Kendra, New Delhi.
2. Sh. M.P. jaipuria, 52 Janpath Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

N/S

INSPECTION REPORT

1. Name & address of the building : 52 Janpath Connaught Place, New Delhi.
2. Type of Occupancy : Business Building Gr. + Mezzanine + 3 upper floors
3. Type of Case : Fresh
4. Details of previous NOC : F.6/DFS/MS/GH/NDZ/2014/1409 dated 14/11/2014
(Ground floor Restaurant)
5. Fire Safety directives Letter No. : F.6/DFS/MS/BP/2011/3665 dated 22/12/2011
- 6 Date of inspection : 14/02/2015
- 7 Name of the Inspecting Officer : Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer
from the building side : Sh. B.L. Mangal (GM)
- 9 Year of Construction : Occupied in 1936
10. Applicant's letter No. : No. Nil dated 11/02/2015.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements Existing	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9Mtr.	12 mt	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	04	MR
	• Basements	NA	NA	NA
	b.Width of staircases			
	• Upper floors	1.25 mtr & 0.90 mtr.	1.50 mt., & 0.90 mtr. 2 Nos 2 Nos	MR
	Basements	NA	NA	NA
	c..Protection of exits			
	• Fire check door	NA	NA	NA
	•			

MMS

2/4

	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	02	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	02 mt	02 mtr. & 1.5 mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	12	15	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	YES	Provided	MR
6	First - Aid Hose Reels			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Gr. floor	Gr. floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	• Basements	NA	NA	NA

MR

	Ground Floor	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	100mm	100mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02	02	MR
	<ul style="list-style-type: none"> Hose Box 	02	02	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> auto Staring/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 	NA	NA	NA
	<ul style="list-style-type: none"> Discharge of pump 	900 LPM & 180 LPM	900 LPM & 180 LPM	MR
	<ul style="list-style-type: none"> Head of the pump 	30 mt	30 mt	MR
	<ul style="list-style-type: none"> Power supply 	Requried	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump 	NA	NA	NA
14	Captive water Storage for fire fighting	NA	NA	NA
	<ul style="list-style-type: none"> Under ground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> Draw of connection. 	NA	NA	NA
	<ul style="list-style-type: none"> Fire service inlet 	NA	NA	NA
		NA	NA	NA

me

N/c

	<ul style="list-style-type: none"> Access to tank Overhead Tank capacity 	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage	Requried	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	Provided	NA
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA
	<ul style="list-style-type: none"> Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> Detector system panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR

Restaurant at Ground floor (A-Block) has been issued Fire safety Certificate vide this letter No.F.6/DFS/MS/GH/NDZ/2014/1409 dated 14/11/2014. All fire fighting systems installed as per guide line issued vide letter No. F.6/DFS/MS/BP/2011/3665 dated 22/12/2011. The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

M.K. Sharma

Name :- Sh. M.K. Sharma

Designation :- A. D.O. (CC)



Do to D

*Aschmid
9/3/15*