

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/school/2015/52/487

Dated: 07/04/2015

FIRE SAFETY CERTIFICATE

Certified that **B. D Jain Public School, C-41, Vijay Vihar, Phase II, Rohini, Delhi-110085** comprised of **Ground + One Upper Floor** owned/occupied by **B. D Jain Public School,** has already been issued fire safety certificate vide letter no **F6/DFS/HQ/MS/Cell/2010/2693 dated 17/09/2010.** The premises was re-inspected by the officer from this department on dated **24/03/2015** in the presence of **Mrs. Hemlata (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore complied with the requirements of **Circular issued by Director of Education letter Circular No 262-362 dated 17/01/2005** and the building / premise is fit for occupancy of Group **Class B (Educational)** with effect from **07/04/2015** for a period of **three years,** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 07/04/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250



Copy to:

1. The Principal, B. D Jain Public School, C-41, Vijay Vihar, Phase II, Rohini, Delhi
2. The Director of Education, Old Secretariat, Delhi

2/15

B. D Jain Public School, C-41, Vijay Vihar, Phase II, Rohini, Delhi-110085

INSPECTION REPORT

Ground + One Upper Floor

1. Name & address of the building : B. D Jain Public School, C-41, Vijay Vihar, Phase II, Rohini Delhi.
2. Type of Occupancy : **Educational**
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/HQ/MS/Cell/2010/2693 dated 17/09/2010
5. Fire Safety directives letter No : Director of Education dated 17/01/2005
6. Date of inspection : 24/03/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Mrs. Hemlata Principal
9. Year of Construction : 2005
10. Applicant's letter No. : nil dated 26/12/2015

Plot Area- 450 Sq.mtr. Covered Area-400 Sq.mtr. No of Student- 195 Class Room-13

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	Accessible	Accessible	M/R
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	M/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.5 m	1.50 & 1.20 mtr	M/R
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	--	--	--

	f. Door Size	01 mtr	P	M/R
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	02	12	M/R
			ABC	M/R
		ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One at each floor	P	M/R
		30 m	P	M/R
		5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N/A	N/A	N/A

N/10.

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		450 LPM	450 LPM	M/R
		40 m	40 m	M/R
		R	P	M/R
		R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		5,000 ltr	5,000 ltr	M/R
		R	P	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A


17	Standby power supply	N/A	N/A	
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


Note: - General requirements for schools as per Director of Education circular dated


1. Escape route **Clear**.....
2. LPG cylinders in laboratories ... **Not in use**.....
3. Electric wiring **Concealed**
- ✓ 4. MCB and ELCB at Electric circuit ... **Provided**.....
- ✓ 5. Electric meter board **Not Below**.....
6. Basement use as per BBL 1983 **N/A**.....
7. Emergency telephone no. board **Displayed**.....
8. Generator set **N/A**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/HQ/MS/Cell/2010/2693 dated 17/09/2010 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name
 Designation


 26/3/15


 Signature of the Inspecting Officer
 Name
 Designation

2157092/15
 26/3/15