

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/EH/2015/SZ/1573

Dated: 10/04/15

FIRE SAFETY CERTIFICATE

Certified that the Eating House located at India Islamic Cultural Centre, 87-88, Lodhi Estate, New Delhi-110003, comprised of lower ground floor, ground floor and 1st floor, (eating house at ground floor only) was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2012/1193, dated 02-04-12. The premises was re-inspected by the officers concerned of this department on 18-03-2015 in the presence of Sh. Mohd. Nausherawan (Jr. Manager Administration) and found that the said eating house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (Eating House) with effect from 10/04/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/04/2015 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333



Copy to:-

1. Joint Commissioner of Police (Licensing), 1st floor, P.S.Defence Colony, New Delhi w.r.t. letter No.440/Jt.C.P./Lic/EH/SCN/(DA-1), dated 12.02.2015.
2. M/S India Islamic Cultural Centre, 87-88, Lodhi Estate, New Delhi-110003.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S India Islamic Cultural Centre, 87-88, Lodhi Estate, New Delhi-03.
2. Building is comprised of : Lover ground, ground and 1st floor(Restaurant at Ground floor)
3. Type of Occupancy : Eating House (Assembly Building).
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/EH/2012/1193, dated-02.04.2012.
6. Fire Safety direction letter No :No.F6/DFS/MS/95/437, dated 10.04.1995.
7. Date of Inspection : 18.03.2015
8. Name of the Inspecting Officers: : D.P.Bhardwaj (D.O.), Vedpal (ADO)
9. Name and designation of officer from the building side : Sh. Mohd Nausherawan (Jr. Manager Administration)
10. Year of Construction :2006.
11. Applicant's letter No. : No.IICC/DFS/14-15/D-2/1075, dated 25.02.15.

S.N	Minimum Standards on fire prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks
1	Access to building			
	Road width	12m	18 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	b. Number of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace.	1no.	2nos.	MR
	g. Width of Corridor	2m	2m	MR
	h. Door Size	Required	4nos.=1m, 1no=1.7m & 1no.=1.3m	MR(old Case)
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	Exhaust fan provided	MR

5.	Fire Extinguisher			
	Total numbers	06 nos.	10 nos.	MR
	types	WCO ₂ & ABC	WCO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01no.	01no.	MR
	Length of hose reel hose	30 m	30m	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat & Smoke	Heat & Smoke	MR
	Location of main panel	Reception	Reception at ground floor	MR
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement/Lower ground floor	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements. (Fire fighting system is common for entire building)			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2800LPM	2800LPM	MR
	➤ Head of Main Pump	40m	70m	M.R
	➤ Number of main pumps	01	N.A.	N.A.
	➤ Jockey pump out put	180LPM	180LPM	MR
	➤ Jockey pump head	40m	70m	MR
	➤ Standby pump out put	2800LPM	2800LPM	MR
	➤ Standby pump Head	40m	70m	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

M/S India Islamic Cultural Centre, 87-88, Lodhi Estate, New Delhi-110003.

14	Captive Water Storage for Fire Fighting. (Fire fighting system is common for entire building)			
	Underground tank capacity	100000Liters.	100000Liters.	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	N.A.	Provided	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	30000Ltrs.	30000Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	D.G. Set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/EH/2012/1193, dated 02.04.12 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration please.

Signature of the Inspecting Officer

Name : D.P.Bhardwaj

Designation : Divisional Officer

Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO

