

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2015/SZ/ 486

DATED: 06/04/15

**FIRE SAFETY CERTIFICATE**

Certified that the Mother Teresa Convent School, RZ-705, Gali No.4, Sagarpur (Main) Palam Road, New Delhi-110046, comprised of basement ground plus two upper floors was granted NOC by this department for ground plus one upper floor vide letter No.F6/DFS/MS/2008/940 dated 15.3.2012. The school building was re-inspected by the officer concerned of this department on 27.3.2015 in the presence of Sh.Harjeet Singh (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Letter No: Estate/CC/Fire Safety/2011/3298 Dtd. 01.03.2011 and that the school building is fit for occupancy of class B "Educational Building" with effect from 06/04/15 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 06/04/15 at New Delhi by



(Dr. GC Misra)  
Chief Fire Officer  
Ph. 011-2341433

**Copy to:**

- 1 Director (Education) SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road, New Delhi.
- 2 Manager, Mother Teresa Convent School, RZ-705, Gali No.4, Sagarpur (Main) New Delhi-110046.



## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



## INSPECTION REPORT

1	Name & address of the building	Mother Teresa Convent School, RZ-705, Gali No.4, Main Sagarpur-New Delhi-110046.
2	Type of Occupancy	Educational Building "B"
3	Type of case	Renewal
4	Details of previous NOC	F6/DFS/MS/School/2012/940 Dated. 15.3.2012
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.
6	Date of inspection	27.3.2015
7	Name of the inspecting Officers	ADO S.P. Bhardwaj
8	Name and designation of officers from the building side	Sh. Harjeet Singh (Manager)
9	Year of construction	2006
10	Applicant's letter No.	MTCS/MAR/2015 dated 18.3.2015 <b>(Building having Basement, ground plus Two upper floors)</b>

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	Approachable	5.50 Mtrs.	MR
	2) Gate width	Approachable	250 Cms.	N/A
	3) Width of internal road	N/A	N/A.	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	2 Nos.	2 Nos.	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	Old case	96 & 68 Cms.	MR
	2. basements	Old case	95 & 93 Cms.	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	2 Nos.	2 Nos.	MR
	e. Width of corridor	200 Cms.	200 Cms.	MR
	f. Door size	Old case	88 Cms.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement		Exhaust fan provide	MR
	upper floors	12 a/c per hour & 30 a/c per hour	Natural Vent.	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers		6 Nos	MR
	Types		ABC	MR
	ISI marking	ISI Marked	Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	1 No.	1No.	MR
	Length of Hose reel hose	30 Mtrs.	30 Mtrs.	MR
	Nozzle Diameter	5 mm	5mm	MR
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	Inverter Provided	MR
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100 mm	100 MM	MR
	Number of Hydrants per floor	One	One	MR
	hose Box	Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	Old case	450, 180 LPM	MR
	b. head of the pump	Old case	30 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old case	4000 Ltrs.	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/6

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of FSC issued vide letter no.F6/ DFS/MS/2012/School/940 dated 15.2.2012 is recommended, under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

*Seen*  
*22/13/15*

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designatic ADO (Dwarka)