

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593


No. F.6/DFS/MS/GH/2015/ 52/490

Dated: 07/04/15

FIRE SAFETY CERTIFICATE

Certified that the **Panicker's Guest House** located at 5/22, WEA, Karol Bagh, New Delhi-110005 is comprised of Basement, Ground Floor plus three upper floors, using basement as hall/storage, ground floor as reception & 04 guest rooms, first & second floor each having 07 guest rooms respectively, third floor having 04 guest rooms (Total 22 guest rooms) and a pantry for staff on terrace was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2012/1962 dated 30.05.2012 owned/occupied by Sh. Gopala Krishnan. The guest house building was re- inspected by the officers concerned of this department on 27.03.2015 in the presence of Sh. Harish Singh (Manager) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on... 07/04/15at New Delhi.


G/M

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.)
1st floor, P.S., Defence Colony, New Delhi.
(Re. No.3811/Joint C.P./Lic.(H), Dated 24.02.2015)
2. Sh. Gopala Krishnan Owner)
Panicker's Guest House, 5/22,
WEA, Karol Bagh, New Delhi – 110005.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

M/19.

Basement, Ground Floor plus three upper floors.

INSPECTION REPORT

1. Name & address of the building : Panicker's Guest House, 5/22, WEA, Kasol Bugh
2. Type of Occupancy : Residential (Guest House) N.D-05.
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F-6/DFS/MS/GH/2012/1962 Date 30.05.2012
5. Fire Safety directives letter No : —
6. Date of inspection : 27.03.2015
7. Name of Inspecting Officer : D.O S.K. Tomar & A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Harish Singh (Manager)
9. Year of Construction : Before 2001
10. Applicant's letter No. : 3811/Joint C.P/LIC.(H) dated 24.02.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	06 mtr	MR
	• Gate width	—	180 cms	MR
	• Width of internal road	—	—	—
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	One	One	MR
	• Basements	-do-	-do-	MR
	b. Width of staircases			
	• Upper Floor	125 cms	130 cms	MR
	• Basements	-do-	132 cms	MR
	c. Protection of exits			
	• Fire check door	—	Provided	MR
	• pressurization	—	—	—
	d. No. of continuous staircases to terrace	—	One	—
	e. Width of Corridor	—	500 cms, 200, 125 cms	—
	f. Door Size	—	90 cms x 202 cms 78 cms x 205 cms	—
3.	Compartmentation			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	Sealed	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fans are Provided	MR
	• Upper floors		Natural Ventilation	MR

N/20.

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	Two at each floor ABC, Co ₂ , WCo ₂ ISI marked	Provided - do - ISI Marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided - do - - do -	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	- - - - -	- - - - -	- - - - -
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required - -	Provided - -	MR - -
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	- - -	- - -	- - -
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- -	- -	- -
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	- - - - - - - - - -	- - - - - - - - - -	- - - - - - - - - -

N/21

5/22, WEA, Karol Bagh,
New Delhi - 110005.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		-	450 LPM	MR, Old Pose
		-	30M	-do-
		Required	Provided	MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	5000 Ltr	MR, Old Case
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	-
		-	-	-
		-	Provided	MR
		Required	-do-	MR
		-do-	-do-	MR
17.	Standby power supply	Required	D.G. Set of 125KVA	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

(10)

N/22.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2012/1962 dated 30.05.2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



S.K. Tomar
30/5/15

Signature of Inspecting Officer
Name S.K. Tomar
Designation Divisional Officer

P.S. Sahiya
28/3/15

Signature of Inspecting Officer
Name P.S. Sahiya
Designation Asstt. Divisional Officer